

ADDENDUM



Date: October 28, 2011

Project: WSC – Hahn Hall Updates
Wayne, Nebraska

To: Bidding Contractors

Project No.: 11020-212

Addendum No.: 3

CC:

This addenda is issued by the Architect/Engineer to all known bidders before receipt of proposals. Bidders shall acknowledge the receipt of this Addendum on their bid form and all information and instructions given herein shall become a part of the Contract Documents.

GENERAL

Prior Approvals – If not specifically called out as OR EQUAL under the specified product the following substitutes are acceptable as long as they meet specification; this is not a formal approval that can only be determined at shop drawing/submittal review stage.

Existing elevator modifications	Schumacher Elevator Co.
---------------------------------	-------------------------

CLARIFICATIONS

1. Vault 104E and File Room 219 are to receive carpet and base as call out in finish schedule. Drawing sheets A9.1 & A9.2 do not show the hatch which is incorrect.

CHANGES TO PROJECT MANUAL

21 10 00 – Water-Based Fire Suppression Systems

1. Paragraph 1.03: Deleted this in its entirety.

CHANGES TO PROJECT DRAWINGS

All work shall be in accordance with the terms, stipulations, and conditions of the original contract.

Mechanical

Sheet U1.1

1. CLARIFICATION - Delete electrical light fixture Types 18, 19, and circuiting shown on this plan. Electrical utilities are shown for reference only. Refer to ME0.1 for Electrical Site Plan.

ADDENDUM



Electrical

Sheet E1.1A

1. Stair Landing 106 – Provide new fixture Type 27 in drywall ceiling and connect to normal switched circuit: Lithonia 2SP8 F 2 32 A12125 MVOLT GEB10IS. New Type 2E and Type 7E shown on plans at this landing shall have flanged trim for installation in drywall ceiling.

Sheet E1.2A

1. Stair Landing 306 – Provide 'RL' fixture in same location as Type '7' fixture shown on E1.2

By:

Kyle Wilkinson and Jeff Johnson

Date:

10/28/11