

ADDENDUM NO. 1
CITY OF SEWARD, NE
6TH STREET WATERMAIN REPLACEMENT
SCHEMMER PROJECT NO. 09083.001

Addenda are instruments issued by the City prior to the date for receipt of offers which will modify or interpret the specification document by addition, deletion, clarification, or correction.

Please acknowledge receipt of this addendum in the space provided in the bid form.

TO ALL PROSPECTIVE BIDDERS:

The following items have been added or deleted:

1. NA

The following items have been modified/clarified:

1. Section 23.03 Part G. POLYVINYL CHLORIDE (PVC) PIPE of chapter 23 of the City of Lincoln Standard Specifications for Municipal Construction is modified as follows:

Polyvinyl Chloride (PVC) pipe shall conform to AWWA C900-16. All pipe 12" in diameter or smaller shall be PVC 1120 DR **18 44** with O.D. conforming to that of ductile iron pipe unless otherwise specified. PVC pipe larger than 12" in diameter shall be PVC 1120 DR 18 conforming to that of cast iron pipe unless otherwise specified. Joints shall be push-on type with rubber compression ring joints conforming to "Standard Specification for Elastomeric Seals (Gaskets) for Joint Plastic Pipe" ASTM F477.

All other terms and conditions of the Contract Documents including Special Provisions, specifications and drawings shall remain unchanged and in effect.

Dated this 8th day of January 2024.

END OF ADDENUM NO. 1