

**ADDENDUM NO. 2**  
**CITY OF SEWARD, NE**  
**6<sup>TH</sup> STREET WATERMAIN REPLACEMENT**  
**SCHEMMER PROJECT NO. 09083.001**

Addenda are instruments issued by the City prior to the date for receipt of offers which will modify or interpret the specification document by addition, deletion, clarification, or correction.

Please acknowledge receipt of this addendum in the space provided in the bid form.

**TO ALL PROSPECTIVE BIDDERS:**

**The following items have been added or deleted:**

1. NA

**The following items have been modified/clarified:**

1. Section 23.01 MATERIALS PURCHASED FROM THE CITY of chapter 23 of the City of Lincoln Standard Specifications for Municipal Construction is void.

The Contractor shall provide all materials for the project.

2. Section 23.02 CONSTRUCTION SERVICES PURCHASED FROM THE CITY of chapter 23 of the City of Lincoln Standard Specifications for Municipal Construction is void.

- The Contractor shall be responsible for flushing and disinfection per the special provisions.
- The Contractor shall be responsible for abandonment of watermain per other sections within chapter 23 of the City of Lincoln Standard Specifications for Municipal Construction.
- The Contractor shall coordinate with City of Seward staff on watermain shutdowns.

3. Section 23.03-N COPPER SERVICE PIPE of chapter 23 of the City of Lincoln Standard Specifications for Municipal Construction is void and replaced with the following:

POLYETHYLENE SERVICE PIPE. Polyethylene service pipe shall be Class 200, according to AWWA C901.

4. Section 23.03-O SERVICE PIPE CONNECTORS of chapter 23 of the City of Lincoln Standard Specifications for Municipal Construction is void and replaced with the following:

SERVICE PIPE CONNECTORS. All connectors intended for use Polyethylene service pipe must be submitted to and approved by the City of Seward prior to installation or payment.

5. Paragraph 3 and 4 of Section 23.03-R TRACER WIRE of chapter 23 of the City of Lincoln Standard Specifications for Municipal Construction is void. Anodes will not be required at dead-end mains.
6. Section 23.20 CATHODIC PROTECTION of chapter 23 of the City of Lincoln Standard Specifications for Municipal Construction is void.

All other terms and conditions of the Contract Documents including Special Provisions, specifications and drawings shall remain unchanged and in effect.

Dated this 9<sup>th</sup> day of January 2024.

**END OF ADDENUM NO. 2**