



DATE ISSUED February 29, 2024

ADDENDUM # 3

ENGINEER Engineering Technologies, Inc.
825 M Street, Suite 200
Lincoln, NE 68508

ETI PROJECT # 2023-193

PROJECT Schuyler Central High School – HVAC
Upgrades

The Architect issues this Addendum to all known bidders before receipt of proposals. Bidder shall acknowledge the receipt of this addendum on their proposal sheet and all information contained herein shall become a part of the contract documents.

ADDENDUM:**GENERAL ITEMS – ROOF****1. Clarification - HVAC Penetrations Through Existing Roof:**

- A. The Contractor shall be responsible for sealing all penetrations through the existing roof below the new and existing metal roofing. The existing metal roofing panels will be removed by the metal roofing contractor and the new and existing metal roofing panels will not be installed/reinstalled for a period of time after the ductwork penetrations are installed. To protect the inside of the building, all HVAC penetrations will be required to be sealed under this scope of work.
- B. The metal roofing contractor (outside of this scope of work) will be responsible for sealing all of their own roof membrane/deck penetrations. The metal roofing contractor is not responsible for sealing any penetrations through the existing roof that are created by this Contractor (i.e. ductwork, electrical, temperature controls, etc.).

END OF ADDENDUM