

### **ADDENDUM NO. 3**

## **MISSOURI VALLEY FIRE STATION ADDITION MISSOURI VALLEY, IOWA**

**DATE OF ADDENDUM ISSUE:** April 3<sup>rd</sup>, 2024  
**DATE OF BID OPENING:** April 10<sup>th</sup>, 2024  
**PROJECT NO.:** 232908

NOTE TO ALL PLAN HOLDERS: Please insert this Addendum into your copy of the contract documents for the above-named project. The following changes to the contract documents are issued by the Architect/Engineer, shall be attached and made a part of the plans and specifications, shall be acknowledged with the bidder's proposal and shall have the same force and effect as though a part of the original issue. All other stipulations and requirements of the plans and specifications remain in effect.

### **CHANGES TO THE SPECIFICATIONS**

#### **SECTION 042000, UNIT MASONRY, PAGE 04000-6 :**

- a. Refer to Paragraph #1.4 (C), Samples for Verification. Clarification: the brick product and mix specified represents the Architect's best effort to match the existing City Hall brick, but remains a *basis-of-design* specification only. While other brick manufacturers and styles will technically be considered, Contractor should not presume equal status *prior to bid* to that specified, unless approved in writing by Architect.
- b. Refer to Paragraph #2.4 (B) subparagraph #1, Clarification: the paragraph wording stating: "The brick shall be laid in a common bond with header courses at every sixth course and soldier courses as shown on the drawings", refers to the existing City Hall brick coursing, with header brick every 6<sup>th</sup> course, which shall be matched for the Addition brick, despite not being shown in the Exterior Building Elevations drawings, due to the small scale.
- c. Refer to paragraph #2.6 (E). Delete paragraph "E" entirely, referencing seismic anchors.

### **CHANGES TO THE DRAWINGS**

#### **SHEET #A4.2:**

- a. Refer to Detail #2/A4.2, WALL SECTION. Change notation, lower right-hand side referring to brick ties to read: "BRICK TIES TO SUBSTRATE @ 16" O.C. VERTICALLY AND HORIZONTALLY".

***Please acknowledge receipt of this Addendum #3 on your bid form.***

Respectfully Submitted,  
**PROCHASKA & ASSOCIATES**

BY:



\_\_\_\_\_  
Curtis A. Field, AIA

Attachments: None