

## ADDENDUM ONE

DATE: May 12, 2026

TO: PROSPECTIVE BIDDERS

FROM: **EAGLE ENGINEERING GROUP**  
12100 W Center Road, Suite 803  
Omaha, Nebraska 68144

RE: 2026 Concrete Pavement Repair  
Gretna, Nebraska  
EEG #26-18

This addendum forms a part of the Contract Documents and modifies the original Contract Documents, dated April 15, 2026, as noted below. Acknowledge receipt of this addendum in space provided on the Bid Form. FAILURE TO DO SO MAY SUBJECT BIDDER TO DISQUALIFICATION

### CHANGES TO PROCUREMENT AND CONTRACTING REQUIREMENTS

#### 1. 00 41 00 BID FORM

- A. STRIKE "OPW 4000" on bid items 4 and 5.

### CHANGES TO PROJECT MANUAL

#### 1. STANDARD SPECIFICATIONS

- A. ADD the following new paragraph after Paragraph 1.01.A:

- i. "1.02 SPECIAL PROVISIONS

- 1.02.1 SECTION 500 RIGID PAVEMENT, 500.02 Material Requirements, A. Cement for Portland Cement Concrete (PCC) Cement shall be Type I/II in accordance with ASTM C150, Specification for Portland Cement including Table 2 (Maximum Equivalent Alkalies requirements only) and Table 3 and the Nebraska Department of Transportation (NDOT). Blended hydraulic cements Type IL is not allowed.


- 1.02.2 SECTION 500 RIGID PAVEMENT, 500.02 Material Requirements, J. PCC Mix Design Proportioning and Required Properties. Mix designs may be City of Omaha 2014 Standard Specifications L65AE or NDOT 47B-Special-3,625 or approved equal."

CHANGES TO DRAWINGS

1. SHEET 2 GENERAL NOTES

A. DETLETE NOTE 20 and insert the following in its place:

- i. "Concrete pavement mix shall be 6-1/2 sack cement and a 28-day compressive strength of 3,625 psi."



Gregory E. Perry, PE

END OF ADDENDUM