

Addendum 1



1800 O Street, Ste. 104, Lincoln, Nebraska 68508 (402) 477-6161

November 18, 2011

Bus Washing Electrical and Piping Upgrade

Alvine No. 2011 2207

Bid Date: November 22, 2011

This addendum is hereby made a part of the contract documents to the same extent as though it were originally included therein. Specifications and drawings shall be considered modified or revised as hereinafter described. Revisions to the drawings are referenced by the drawing number.

Changes to Drawings

Electrical Drawing Items:

1ED1. Sheet E101 – First Level Floor Plan - Electrical

1. In order to get the two transformers up into the second level the Contractor shall remove and reinstall the existing metal ladder.
2. In panel 'M' move an existing 20/2 breaker up one pole space in order to make room to install the new 15/3 breaker.

END