



2970 N 10th St, Gering, NE 69341
(308) 635-2213 FAX (308) 635-0182

Web: www.paulreedconstruction.com
E-mail: prc@paulreedconstruction.com

**Inland Truck Parts Company
New Truck Service Center, North Platte NE**

Addendum #3

Location: Inland Truck Service Center
3820 South Newberry Access,
North Platte, NE

Issue Date; April 26, 2012

Bid Clarifications;

Question; On sheet E-202 note 3, there is an outlet for a steam washer shown on the north wall that is not listed in the panel schedule on sheet E-401 thus we can not tell what size breaker or wire feed it.

Answer; Figure a 30A/3P circuit for bidding purposes, but verify actual requirements with owner prior to installation, as the pressure washer is an owner-furnished piece of equipment.

•

Question; Do we need to put in curb grinding for the new drive entrances? Not shown.

Answer; Cut and remove existing curb (See Note #1 on sheet C-101). You will need to dowel into the existing pavement, using the typical isolation joint shown on the drawings. Do NOT grind the existing curb.

•

Question; The plans don't show a P.I.V. on the fire line going in the fire line to the building. Do you want us to include a P.I.V. in our Bid?

Answer; Assume the state Fire Marshall will require one. Please include a PIV on the fire line.

•

Question; I have a question about panel RP it is for future connection of owner furnished rebuild shop equipment. Is there a list of breakers needed in this panel. Is there equipment that needs wired, that we need to put in our bid.

Answer; We will address pricing for hookup of owner furnished equipment at a later time. Do not include in this bid.