

155-056-10

### **ADDENDUM NO. 1**

The Architect/ Engineer issues this addendum, applicable to the above named project, to all known Contractors before receipt of proposal.

This addendum includes Item Number 1-1. This addendum item shall be fully incorporated into the Bidding/Contract Documents and have the same force and effect as though originally included.

The Bidder shall acknowledge receipt of this Addendum No. 1 on the Bid Proposal Form in the place provided.

#### **Electrical**

#### **Drawings**

**Item 1-x:       Sheets E2.1, 2.2, 2.3, 2.4, and 2.5, Power & Auxiliary Systems Plans**

As per the original set of drawings, Addendum #4, Item 4-6 the motor size for RF-1 (typical for 5) increased to 3hp. With this change the mechanical engineer noted to coordinate the associated electrical requirements. These associated electrical changes are shown on the 'rebid' set of drawings.

END OF ADDENDUM NO. 1