

ADDENDUM NO. 2

PROJECT NAME: Abel Hall Roof Replacement
UNL PROJECT NUMBER: C061P106

CONSULTANT: Erickson Sullivan Architects, P.C.
ADDRESS: 209 S. 9th Street
Lincoln, NE 68508

DATE OF ISSUANCE: May 8, 2012
DATE OF BID OPENING: May 15, 2012

The bid documents dated **April 20, 2012** for the above referenced project are amended by this addendum.

NOTICE: This Addendum is issued to all interested prospective bidders as an amendment to the project manual or other parts of the bidding (contract) documents for the above named project. Reference to this Addendum must be included in the Bid proposal. The information contained herein shall be fully incorporated into the contract documents as though originally included therein.

MODIFICATIONS TO THE ARCHITECTURAL DRAWINGS:

ARCHITECTURAL DRAWINGS:

AD1.1. Substitution – Membrane Product Substitutions from Carlisle-Syntec Systems and Mule-Hide Products Co., Inc. are acceptable substitutions provided that the following criteria have been met:

A request for substitution constitutes a representation that the submitter:

1. Has investigated proposed product and determined that it meets or exceeds the quality level of the specified product.
2. Will provide the same warranty for the substitution as for the specified product.
3. Will coordinate installation and make changes to other Work which may be required for the Work to be complete with no additional costs to the Owner.
4. Waives claims for additional costs or time extension which may subsequently become apparent.

AD1.2. Revision - Specification Section 07 50 00 Membrane Roofing, 2.5 Metal Accessories,
A. Parapet Copings,
1. Wind Performance item b should read
b. Provide product listed in current Factory Mutual Research Corporation Approval Guide with at least **FM 1-90 rating**.

END OF ADDENDUM NO. # 2