



ADDENDUM NO. 2

1.01 NOTICE TO BIDDERS

- A. Date: 8 October 2012
- B. From: Bahr, Vermeer and Haecker Architects, Ltd.
- C. To: Prospective Bidders.
- D. Project: Lexington Public Schools
Lexington Middle School / Community Recreation Facility Addition
Bid Packages No. 4 – No. 7
Lexington, Nebraska
- E. This addendum is issued by the Architect to all bidders of record prior to receipt of proposals. Bidders shall acknowledge receipt of this addendum by so indicating on the Bid Form. Failure to do so may subject Bidder to disqualification.
- F. All information and instructions given herein shall become a part of the Contract Documents.
- G. This Addendum contains one (1) total pages with no attachments.

1.02 PROJECT MANUAL – CIVIL

- A. Section 312000 - EARTHMOVING
 - 1. Reference Paragraph 2.01 A. 1.; delete this paragraph in it's entirety and replace with the following:
 - a. Top soil shall be placed and supplied by the Contractor.
 - 2. Reference Paragraph 3.10 A.; delete this paragraph in it's entirety and replace with the following:
 - a. Contractor shall rough grade the entire site to within 6" below final grade. Upon completion of rough grading, the Contractor shall spread topsoil over all areas graded under this Contract and nor receiving other surfacing or in the building area. Before spreading topsoil, graded areas shall be scarified for a depth of 3 inches, and all settlements and washes shall be repaired. Finish grade shall be held 1 inch below adjacent sidewalks, curbs, and pavement. Topsoil shall be free of rocks, rubble, wood, and other undesirable material.

END OF ADDENDUM No. 2