



Addendum #5 - Bid Package #6929-08

Project Name: Lincoln Public Schools District Office
5901 'O' Street
Lincoln, NE
Project No.: 11065
Issued: November 27, 2012

This Addendum is issued by Hampton Construction to all known sub-contractors working on the preparation of proposals associated with the Bid Documents dated September 7, 2012. This Addendum is to authorize the use of the following information in preparing proposals for the above named project.

GENERAL QUESTIONS AND CLARIFICATIONS

ADD 5-1. Various details on sheets A600 and A601 identify a terrazzo wall base. The base is graphically shown as a base independent of the terrazzo floor. This was initially shown that way because the details were used for both terrazzo and wood base conditions. It should be noted that at terrazzo wall base locations, the terrazzo base is to be a cast-in-place cove base, integral with the terrazzo flooring.

ADD 5-2. Terrazzo Wall Base:

Question: *There is no elevation of the east wall in area 180D. Looking at the wall sections it does not appear there is a terrazzo base along this wall. Can you confirm that this is correct or let me know if the wall is to have a wall base?*

Response: Our wall sections do not typically show or call out the wall base whether it is wood, vinyl or terrazzo. The room finish schedule indicates the material requirements for the wall base. Addendum #2 modified the room finish schedules and indicated that there was to be a terrazzo wall base in Room 180D.

MODIFICATIONS TO THE SPECIFICATIONS

ADD 5-3. Refer to Section 096623 "Resinous Matrix Terrazzo Flooring", Article 3.3, Paragraph F; Replace this paragraph with the following:

F. Flexible Reinforcing Membrane:

1. Provide reinforcing membrane at locations where substrate joints do not align with terrazzo jointing. Substrate joints should be filled with 100% solids epoxy and then treated with flexible membrane and reinforcement per manufacturer's recommendations.

MODIFICATIONS TO THE DRAWINGS

ADD 5-4. Refer to Detail D13/A600; Keynote 096813.A near the center of the detail should be changed to keynote 096623.A

End of Addendum #5, Bid Package #6929-08