

# Addendum 2



1800 O Street, Ste. 104, Lincoln, Nebraska 68508 (402) 477-6161

January 14, 2013

State of Nebraska HVAC Replacement for South Cottages  
Beatrice State Developmental Center

Alvine No. 2011 2582

**Bid Date: January 22, 2013 - Revised per this Addendum No. 2.**

*This addendum is hereby made a part of the contract documents to the same extent as though it were originally included therein. Specifications and drawings shall be considered modified or revised as hereinafter described. Revisions to the drawings are referenced by the drawing number.*

## **Changes to the Project Manual**

### General Specification Items:

2GS1. Notice to Bidders

1. **Revise the Bid Time and Bid Date to be "3:00 p.m. on Tuesday, January 22, 2013" instead of "3:00 p.m. on Tuesday, January 15, 2013".**

### Mechanical Specification Items:

2MS1. Section 23 01 30.51 - HVAC Air Duct Cleaning

1. Page 23 01 30.51-2, Article 2.3.A, remove the word "anti-microbial" and replace with the following:

"Surface Coating for Fibrous Glass Materials: Black, synthetic latex or water-based, low VOC; mold and mildew resistant, flame spread index less than 25, smoke developed index less than 50, when tested in accordance with ASTM E84. Apply this surface coating to areas of existing lined and unlined ductwork as indicated on the project drawings."

## **Changes to Drawings**

### Mechanical Drawing Items:

2MD1. Sheet M001 – Site Plan - Mechanical

1. Add the following to the end of Flag Note No. 3:

"Black Hills Energy is not working directly for the Owner on this project. The work performed by Black Hills Energy is to be included in the scope of work by the Contractor under this contract."

END

PAB/mkm