

Sampson Construction Co., Inc.
3730 South 14th Street
Lincoln, NE 68502
Phone: (402) 434-5450
FAX: (402) 434-5466

Bid Bulletin #03

PROJECT: Seward Memorial Library
Lower Level Renovation
Seward, NE

DATE: February 8, 2013

This Bid Bulletin includes items 1-1 through 1-1. Each item shall be fully incorporated into the Bidding/Contract Documents and have the same force and effect as though originally included. Bidders shall acknowledge receipt of this Bid Bulletin on the bid form.

Item 1-1 Attached is Addendum #3 dated 2/8/13 from The Clark Enersen Partners.

END OF BID BULLETIN #03

578-004-11

ADDENDUM NO. 3

The Architect/ Engineer issues this addendum, applicable to the above named project, to all known Contractors before receipt of proposal.

This addendum includes Item Number 3-1 thru 3-3. This addendum item shall be fully incorporated into the Bidding/Contract Documents and have the same force and effect as though originally included.

The Bidder shall acknowledge receipt of this Addendum No. 3 on the Bid Proposal Form in the place provided.

MECHANICAL

Drawings

Item 3-1: Refer to Sheet M7.01 – Heat Pump Schedule

Johnson Controls is an approved two stage heat pump manufacturer.

Item 3-2: Refer to Sheet M7.02 - Diffuser, Register, and Grille Schedule

D-1 to be a steel Titus Omni – NT diffuser.
D-2 to be a steel model Titus TMR diffuser.
G-1 to be a steel model Par-NT grille.
G-2 to be a steel PXP-NT grille.

Item 3-3: Refer to Sheet M7.02 – ERU-1 Schedule

The MOCP for the single point electrical connection is 30 Amps at 480V / 3 Phase / 60HZ.

END OF ADDENDUM NO. 3