



ARCHITECTURE • ENGINEERING • INTERIOR DESIGN

ADDENDUM

PROJECT: University of South Dakota
Patterson Hall
Lecture Hall Renovation
Vermillion, South Dakota

ADDENDUM NUMBER

AD-1

ISSUED BY:

Jon Dalton, Electrical Engineer

PROJECT #: 12-0066

DATE ISSUED: Monday, March 18, 2013

This addendum is issued by the Architect to all known bidders before receipt of proposals, for the purpose of explaining, interpreting, or modifying the original plans and specifications. When enumerated by the bidder upon the proposal sheet, the information or instructions given hereon will be equally binding upon all parties as if included in the original plans and specifications.
BIDDER MUST ENTER THE NUMBER OF THIS ADDENDUM ON HIS PROPOSAL SHEET

THE FOLLOWING ITEMS ARE APPLICABLE TO THE DRAWINGS:

AD-1, ITEM 1:

In reference to Sheet E-101, add the following text to keyed note #16. "Provide and install new 100 amp 3 pole beaker in panel "DP" in spare breaker location, return removed breaker to Owner. Connect RTU-1 branch circuit to new breaker."

END AD-1