

721-003-12

ADDENDUM NO. 4

The Architect/ Engineer issues this addendum, applicable to the above named project, to all known Contractors before receipt of proposal.

This addendum includes Item Number 4-1 thru 4-3. This addendum item shall be fully incorporated into the Bidding/Contract Documents and have the same force and effect as though originally included.

The Bidder shall acknowledge receipt of this Addendum No. 4 on the Bid Proposal Form in the place provided.

ARCHITECTURAL

Specifications

Item 4-1: Section 075323 – EPDM Roofing

Delete Paragraph 2.5 Substrate Boards.

Drawings

Item 4-2: Sheet A1.06 – Roof Plan

Clarification: Existing fully adhered EPDM roof and all existing 4” insulation in the Area from Grids 1-3 and A-G.9 shall be removed in its entirety and replaced with new 4” base and new tapered insulation as per Contract Documents. All ties to existing ballasted EPDM roof shall maintain all roof watertight integrity and warranties.

Item 4-3: Sheet A6.01 – Lobby / Teller / Book Keeping

Clarification: Refer to Interior Elevation Detail 6 Tellers South: Area indicated for interior signage “The Copy” shall be as per the Monument Sign indicated on Detail 1/L6.02.

END OF ADDENDUM NO. 4