

ADDENDUM #4

NORTH PLATTE COMMUNITY COLLEGE SOUTH CAMPUS CAFETERIA ADDITION NORTH PLATTE, NEBRASKA 1001

Wilkins Hinrichs Stober Architects, L.L.C.
2908 West 39th Street, Suite A
Kearney, Nebraska 68845
308-237-5787

Date Issued: March 22, 2013

Bid Date: March 25, 2013

TO ALL BID DOCUMENT HOLDERS OF RECORD:

Acknowledge receipt of this addendum by inserting its number in the space provided on the BID FORM. Failure to do so may subject Bidder to disqualification. This Addendum forms a part of the BIDDING DOCUMENTS and modifies them as follows.

Addendum #4 - #1

ADDENDUM #2 - #19

Retract this addendum note. Detail 5/S3.1 still applies at this location.

Addendum #4 - #2

SHEET AD1.0 – DEMOLITION FLOOR PLAN

1/AD1.0 – DEMOLITION – FIRST FLOOR: At COMMUNITY ROOM 10 and LAUNDRY 13 add the following note: "REMOVAL OF FLOORING AND WALL BASE IN THIS ROOM IS BY ALTERNATE NO. 3 ONLY".

Addendum #4 - #3

SHEET A4.0 – ROOF PLAN

ROOF ASSEMBLIES: RA-2 – Delete the requirements for the 30LB FELT. CLARIFICATION NOTE: Since the entire roof, with the exception of the EPDM portion, is required to receive Ice and Water Shield, the 30 LB felt is not required.

Addendum #4 - #4

SHEET A9.0 – ROOM FINISH SCHEDULE

ROOM FINISH REMARKS NOTE 6: Add the following sentence to Note 6: "INSTALL NEW WALL BASE AT ALL WALLS, VB-1".

GENERALS

Wayne Dowhower Construction	308-532-9388	308-532-9389
Sampson Construction	308-865-1375	308-865-1381
Steele's Roofing & Construction	308-532-0575	308-534-6268