

ADDENDUM #1
CENTRAL COMMUNITY COLLEGE
ATHLETIC COURTS
COLUMBUS, NEBRASKA
1302

Wilkins Hinrichs Stober Architects, L.L.C.
2908 West 39th Street, Suite A
Kearney, Nebraska 68845
308-237-5787

Date Issued: March 25, 2013

Bid Date: March 28, 2013

TO ALL BID DOCUMENT HOLDERS OF RECORD:

Acknowledge receipt of this addendum by inserting its number in the space provided on the BID FORM. Failure to do so may subject Bidder to disqualification. This Addendum forms a part of the BIDDING DOCUMENTS and modifies them as follows.

Addendum #1 - #1

SHEET C-4 SITE GRADING & DRAINAGE PLAN

Refer to Detail 2, Segmental Retaining Wall: Rockwood Classic 6 and Denver 6" SRW has been approved as equivalent retaining wall types. Provide in color and face texture specified. Make adjustments to typical retaining wall section as may be required per manufacturer's installation recommendations.

Addendum #1 - #2

SHEET E-1 ELECTRICAL SCHEDULES & DETAILS

Refer to Luminaire Schedule:

1. No alternates will be accepted for the type S fixture. This luminaire and pole are to match existing equipment on site.
2. Type S1: Subject to final shop drawing review, Central Sales has provided an alternate luminaire by Lithonia and AES Lighting group has provided an alternate by McGraw-Edison.
3. Type S2: Subject to final shop drawing review, AES Lighting Group has provided an alternate luminaire by Dals Lighting.
4. Revise Luminaire Schedule Remarks 1 to: Five poles shall be configured for cameras at 15'. All other items remain the same.

Addendum #1 - #3

SHEET E-2 ELECTRICAL SITE PLAN

Move (4) S-1 fixtures around volleyball court from 15' away from play zone to 17' away from play zone.

GENERALS

BD Construction-Columbus	402-564-1225	402-564-9999
Bierman Contracting	402-564-4749	402-564-4658
Fauss Construction	402-654-3392	402-654-3394