

## ADDENDUM #2

# University of Nebraska - Kearney CENTENIAL TOWERS – EAST RENOVATION KEARNEY, NEBRASKA 1244

Wilkins Hinrichs Stober Architects, L.L.C.  
2908 West 39th Street  
Suite A  
Kearney, Nebraska 68845  
308-237-5787

Date Issued: March 29, 2013

Bid Date: April 2, 2013

TO ALL BID DOCUMENT HOLDERS OF RECORD:

Acknowledge receipt of this addendum by inserting its number in the space provided on the BID FORM. Failure to do so may subject Bidder to disqualification. This Addendum forms a part of the BIDDING DOCUMENTS and modifies them as follows.

- 
- |                         |  |
|-------------------------|--|
| <b>Addendum #2 - #1</b> | <b>SPECIFICATIONS SECTION 22 4000 BASIC PLUMBING FIXTURES</b><br>Part 2 – Products, 2.2 Plumbing Fixtures, Paragraph 2.2.G.4 - Add: “k. Moen”  |
| <b>Addendum #2 - #2</b> | <b>SPECIFICATIONS SECTION 22 4000 BASIC PLUMBING FIXTURES</b><br>Part 2 – Products 2.2 Plumbing Fixtures Paragraph 2.2.G.5 - Add: “c. Moen”  |
| <b>Addendum #2 - #3</b> | <b>SPECIFICATIONS SECTION 22 4000 BASIC PLUMBING FIXTURES</b><br>Part 2 – Products 2.2 Plumbing Fixtures Paragraph 2.2.G.7 - Add: “f. Jay R. Smith”  |
| <b>Addendum #2 - #4</b> | <b>SPECIFICATIONS SECTION 23 7200 ENERGY RECOVERY VENTILATION UNITS</b><br>Part 2 – Products 2.1 .A - Add: “6. Annexair”   |
| <b>Addendum #2 - #5</b> | <b>SHEET A9.0 ROOM FINISH SCHEDULE</b><br>At MATERIALS LIST, change MCT-1 to read “MARMOLEUM COMPOSITION TILE 13” x 13” in lieu of “MARMOLEUM COMPOSITION TILE 12” x 12”.  |
| <b>Addendum #2 - #6</b> | <b>SHEET A9.0 ROOM FINISH SCHEDULE</b><br>At MATERIALS LIST, change VB-1 to read “STANDARD COVE ” in lieu of “TIGHTLOCK”.  |
| <b>Addendum #2 - #7</b> | <b>SHEET M6.4 – MECHANICAL SCHEDULES</b><br>HYDRONIC PUMP SCHEDULE – Change pump information for CWP-2 as follows<br>PRM: 1800 / EFFICIENCY: 58.0% / MANF. MODEL NO.: B&G SERIES 80 2X2X7<br>IMPELLER DIA.: 7.0 IN.  |
| <b>Addendum #2 - #8</b> | <b>SHEET 2.0 POWER &amp; SPECIAL SYSTEMS FLOOR PLAN - BASEMENT</b><br>Provide 3 new circuit breakers with locking handles in panel LP1 for the additional power supplies required by the fire alarm system. Provide rough-in for 5 wireless access points.                                   |
| <b>Addendum #2 - #9</b> | <b>SHEET 2.1 POWER &amp; SPECIAL SYSTEMS FLOOR PLAN – 1<sup>ST</sup> FLOOR</b><br>Provide circuits from panel LP1 to Storage Room 131 for fire alarm power supplies. Provide rough-in for 5 wireless access points on the ceilings. One at each point of the building and one in the lounge. |

**Addendum #2 - #10****SHEET 2.2 POWER & SPECIAL SYSTEMS FLOOR PLAN – 2<sup>nd</sup> FLOOR**

Provide circuits from panel LP1 to Storage Room 231, 331, 431, 531, 631 and 731 for fire alarm power supplies. Provide rough-in for 5 wireless access points on the ceilings of each floor. One at each point of the building and one in the lounge.

**Addendum #2 - #11****SHEET E6.1 – LUMINAIRE SCHEDULE**

Subject to final shop drawing review, Central Sales Lighting Company has provided an alternate from Eclipse Lighting for the Type C fixture.

**GENERALS**

Central Contracting Corp, Kearney	308-234-2421	308-237-4767
Lacy Construction, Grand Island	308-384-2866	308-384-2883
Sampson Construction, Kearney	308-865-1375	308-865-1381
Lund Ross Constructors, Omaha	402-342-2810	402-342-8775
Boyd Jones Construction, Omaha	402-553-1804	402-553-5894
Hausmann Construction, Lincoln	402-438-3230	402-438-3235

**PRE BID ATTENDEES**

<b>Name</b>	<b>Organization</b>	<b>Phone</b>	<b>E-Mail</b>
Alan Wedige	UNK	308-865-1700	wedigead@unk.edu
Chane McDowell	Anderson Brothers	308-236-6437	chane_mcdowell@andersonbros.com
Jason Pecik	Anderson Brothers	308-236-6477	jason_pesik@andersonbros.com
David Autry	Melninger Fire	402-466-2616	davidemfpinc.com
Jeff Mashek	Middleton Electric	308-379-9868	jmashek@middletonelectric.com
Dan Clemens	Hausmann Construction	402-613-2536	danc@hausmannconstruction.com
Nick Killough	Kearney Glass, Inc.	308-236-9970	estimating@kearneyglass.com
Pat O'Neill	O'Neill Demo	308-384-1690	Pat@oneillwr.com
Nick Blanchard	Boyd Jones	402-553-1804	estimating@boydjones.biz
Paul Kucera	Kucera Painting	293-1938	
Rob Rasmussen	Lacy Construction	308-380-5094	robassmussen@lacygc
Dennis McLaughlin	Kelly Elec.	308-234-2822	mmclaughlin@kellyelec.com
Brian Cox	UNK	308-865-8176	coxbiz@unk.edu
Chris Melninger	MFP	402-466-2616	chrismfp-ink.com
Jeff Waggoner	Dave Waggoner	308-236-6850	
Steve Frank	Willmar Electric	308-236-5540	sfrank@willamarelectric.com
Mike Evers	Ne Five Sprinkler	381-2033	ryan@nebraskafire.com
Regg Rutt	Rutts Heating and AC	402-462-4857	rrutteruttsheating.com
Dave Barger	Anderson Bros.	308-236-6437	
Chris Larsen	Anderson Bros.	308-236-6437	chris_larsen@andersonbros.com
Roger Scheidies	Bamford, Inc.	308-237-2157	rogs1@citunk.net
Steve Lentell	Central Contracting	308-234-2421	slentell@centralcontracting.net
Scott Brown	Lund-Ross	402-342-2810	scottb@lundross.com
Brad Collison	Cornerstone Electric	308-830-0153	
Jeff Collison	Cornerstone Electric	308-830-2894	cornerstoneelec@charter.net
Bruce Mooers	Electronic Systems Inc.	402-463-0260	elecsys@kdst.net
Jeremy Sklenar	Kelly Electric	308-234-2822	jssklenar@kellyelec.com