



DATE ISSUED 5 April 2013

ADDENDUM # 1

ENGINEER Engineering Technologies, Inc.
825 M Street, Suite 200
Lincoln, NE 68508

PROJECT LPS - Park Middle School
-Fire Alarm Replacement

ETI PROJECT # 2013-012

LPS BID # 7372

The Engineer issues this Addendum to all known bidders before receipt of proposals. Bidder shall acknowledge the receipt of this addendum on their proposal sheet and all information contained herein shall become a part of the contract documents.

ADDENDUM:

GENERAL ITEMS – ELECTRICAL

1. For clarification, the fire sprinkler system shall remain functioning and the monitoring of the fire sprinkler system by the fire alarm system shall be kept in place during the fire alarm replacement process. Provide all necessary provision to comply with this requirement.

END OF ADDENDUM