

ADDENDUM NO. CC-3

BCDM Architects
1015 North 98th Street, Suite 300
Omaha, Nebraska 68114

to the
Bidding Documents

for

22 April 2013

BLOOMER ELEMENTARY SCHOOL
REMODEL
210 S. 7th Street
Council Bluffs, Iowa 51503
BCDM Project No. 3103-01

NOTE: ADDENDA MAY BE VIEWED AT WWW.ADTECHSUPPLY.COM

REMINDER: BID DATE AND TIME: APRIL 23, 2013 AT 2:00 P.M. LOCAL TIME

NOTICE TO BIDDERS: The Project Manual and Drawings for the above referenced project are hereby amended as follows:

PROJECT MANUAL

SECTION 12300 – MANUFACTURED CASEWORK

- a. Page 12300-3, line 51, add the following:
“Field applied edge banding at existing countertops shall be flat PVC 15/16-inch by .018 –inch edge banding. Color to be selected from manufacturer’s standard colors.”

DRAWINGS

SHEET E1-1 First Floor Plan- Lighting

- a. Classroom 119 – Provide two additional network lighting control secondary relay packs and one additional emergency powerpack. Connect so front row is bi-level switched and remaining six fixtures are bi-level switched independently. Coordinate programming of scene controller with engineer.

SHEET E4-1 Electrical Schedules and Details

- a. Lighting Fixture Schedule
1. Fixture type 6 shall be Lithonia (Note 1) #LQM S W 3 R 120/277
 2. Fixture type 7 shall be Focal Point (equal by Philips) #FL6D 13LED L35 LD1 120 RO T BH L6 RO DN CD NP
 3. Fixture type 8 shall be Peerless (equal by Axis, A Light, Selux) #LLWL D 1 28T5 SSH 12FT R12 120 GEB10RS C100

END OF ADDENDUM