

This addendum is issued by the Owner to all known bidders prior to receipt of Proposal. Bidders shall acknowledge receipt of this Addendum by so indicating on the Proposal Form. All information and instruction given herein shall become a part of the Contract Documents.

This addendum contains the following information:

Addendum #1.....	02 Sheets
Architectural Sheet COVER.....(24x36)	01 Sheet
Architectural Sheet AD1.1.1.....(24x36)	01 Sheet
Architectural Sheet AD1.1.2.....(24x36)	01 Sheet
Architectural Sheet A1.1.1.....(24x36)	01 Sheet
Architectural Sheet A1.1.2.....(24x36)	01 Sheet
Architectural Sheet A5.1.....(24x36)	01 Sheet
Specification Manual Section 006000.....	02 Sheets

Total **10 Sheets**

If this addendum appears incomplete, notify the architect immediately.

GENERAL

1. On G1.0, eliminate fire-rated wall type 'R2' as it is not used in the project.

ARCHITECTURAL DRAWINGS

1. SHEET COVER – Revise drawing list as shown
2. SHEET AD1.1.1 – Revise key notes as shown
3. SHEET AD1.1.2 – Revise key notes as shown
4. SHEET A1.1.1 – Revise key notes as shown. Revise elevation tag at Bookstore 110. Eliminate rated wall type 'R2' at mechanical shaft in Lecture Area 200.
5. SHEET A1.1.2 – Revise key notes as shown
6. SHEET A5.1 – See revisions at elevations C1/A5.1 and M10/A5.1

MECHANICAL DRAWINGS

1. SHEET M1.1.3 – Add the following notes:

Testing, Adjusting, and Balancing Notes

1. Prior to mechanical demolition, the testing, adjusting, and balancing contractor shall measure and record the airflow provided to the existing space to be occupied by the School Based Health Center.
2. The space is served by a multi-zone rooftop unit. Verify the unit is operating and in occupied mode prior to performing pre-demolition balancing scope. Existing drawings indicate a total of 1,150 cfm provided to this space.
3. Submit report immediately upon completion of pre-demolition balancing scope.

School-Based Health Center, Bryan High School

APMA Project #12085

8 May 2013

2. Provide fire alarm notifications as follows:
 1. Provide horn / strobe device in Team Room 112.
 2. Provide strobe in Bookstore 110.
 3. Provide Horn / strobe in Waiting 100B.
 4. Provide strobe in Nurse Station 101.
 5. Provide strobe in Lab / Registration 102.
 6. Provide strobe in Exam 103.
 7. Provide strobe in Exam 105.

PROJECT MANUAL

1. Section 006000 – Invitation to Bid: Revised list of bidding document locations.


End of Addendum #1

SCHOOL-BASED HEALTH CENTER

BRYAN HIGH SCHOOL

4700 GILES ROAD
OMAHA, NE 68157

COORDINATING PROFESSIONAL



Perry L. Poyner has acted as the Coordinating Professional on the School-Based Health Center, Bryan High School project.

PROJECT CONTACT INFORMATION

PROJECT PRINCIPAL: PERRY POYNER
PROJECT MANAGER: ERIN TROFHOLZ

MEP ENGINEER:
MORRISSEY ENGINEERING
MECHANICAL ENGINEER: NATE SHEETS
ELECTRICAL ENGINEER: ANDREW LANG
4940 NORTH 118TH STREET
OMAHA, NE 68164
TEL: 402.491.4144


STRUCTURAL ENGINEER
PERFORMANCE ENGINEERING
MARTIN WIEDENMANN
4940 NORTH 118TH STREET, SUITE 200
OMAHA, NE 68164
TEL: 402.255.3825

**ALLEY•POYNER
MACCHIETTO
ARCHITECTURE**


1516 Cuming Street
Omaha, NE 68102
Ph: 402.341.1544
Fx: 402.341.4735
alleypoyner.com



03 may 2013



SECOND FLOOR



FIRST FLOOR

BRYAN HIGH SCHOOL
(SCOPE OF WORK AREAS SHOWN HATCHED)

architectural drawings

- G1.0 GENERAL INFORMATION, REFERENCE SYMBOLS
- AD1.1.1 PARTIAL FIRST FLOOR DEMOLITION PLAN; PARTIAL SECOND FLOOR DEMOLITION PLAN
- AD1.1.2 PARTIAL FIRST FLOOR DEMOLITION PLAN - MENS LOCKER ROOM
- A1.1.1 PARTIAL FIRST FLOOR PLAN; PARTIAL SECOND FLOOR PLAN
- A1.1.2 PARTIAL FIRST FLOOR PLAN - MENS LOCKER ROOM; ENLARGED FLOOR PLAN - SBHC
- A5.1 INTERIOR ELEVATIONS
- A5.2 MILLWORK DETAILS
- A5.3 DETAILS AND WALL SECTIONS
- A6.1 FINISH AND DOOR SCHEDULES, DOOR AND WINDOW TYPES
- A6.2 DOOR DETAILS
- AF.1.1 PARTIAL FIRST FLOOR RCP; PARTIAL SECOND FLOOR RCP


mechanical drawings

- M1.1.1 PARTIAL FIRST FLOOR PLANS - MENS LOCKER ROOM - HVAC
- M1.1.2 PARTIAL FIRST FLOOR PLAN, PARTIAL SECOND FLOOR PLAN - BOOKSTORE - HVAC
- M1.1.3 PARTIAL FIRST FLOOR PLANS - SCHOOL BASED HEALTH CENTER - HVAC
- M2.1.1 PARTIAL FIRST FLOOR PLANS - PLUMBING
- M3.1.1 MECHANICAL SYMBOLS, DETAILS, AND SCHEDULES

electrical drawings


- E1.1.1 PARTIAL FIRST FLOOR PLAN ELECTRICAL DEMOLITION & LIGHTING
- E1.1.2 PARTIAL FIRST FLOOR PLAN ELECTRICAL DEMOLITION & LIGHTING
- E1.1.3 PARTIAL FIRST FLOOR PLAN ELECTRICAL DEMOLITION & LIGHTING
- E2.1.1 PARTIAL FIRST FLOOR PLAN POWER & SPECIAL SYSTEMS
- E2.1.2 PARTIAL FIRST FLOOR PLAN POWER & SPECIAL SYSTEMS
- E2.1.3 PARTIAL FIRST FLOOR PLAN POWER & SPECIAL SYSTEMS

REVISION	ISSUED	DATE
△	ADDENDUM #1	05.08.2013



M1 PARTIAL SECOND FLOOR DEMOLITION PLAN

AD1.1.1 SCALE: 1/4" = 1'-0"



M8 PARTIAL FIRST FLOOR DEMOLITION PLAN

AD1.1.1 SCALE: 1/4" = 1'-0"

DEMOLITION GENERAL NOTES:


1. THE INTENT OF THESE DEMOLITION DRAWINGS IS TO DEFINE A GENERAL SCOPE OF DEMOLITION WORK. THESE DRAWINGS MAY NOT IDENTIFY EVERY ITEM TO BE REMOVED. THE CONTRACTOR IS RESPONSIBLE FOR DETERMINING ALL ITEMS WHICH MUST BE REMOVED TO FACILITATE NEW CONSTRUCTION
2. **NO DEMO OR CONSTRUCTION WORK** TO BE PERFORMED IN HATCHED AREA
3. ITEMS DRAWN BOLD AND DASHED ARE TO BE REMOVED. REFER TO KEYED NOTES FOR SPECIFIC ITEMS
4. REMOVE ALL ABANDONED PIPING, ELECTRICAL CONDUIT, MISCELLANEOUS HANGERS, MISCELLANEOUS DUCTWORK, AND ALL OTHER ABANDONED ITEMS UNLESS OTHERWISE NOTED
5. CONTRACTOR TO SHORE EXISTING STRUCTURE AS NEEDED
6. IDENTIFY EXISTING AREAS OF STRUCTURALLY UNSOUND FLOOR AND FRAMING ELEMENTS FOUND DURING DEMOLITION PROCESS. ADVISE ARCHITECT OF CONDITION
7. COORDINATE ALL REMOVAL AND LOCATION OF WALL AND FLOOR PENETRATIONS WITH NEW CONSTRUCTION
8. DISPOSE OF ALL ITEMS IN ACCORDANCE WITH ALL APPLICABLE REQUIREMENTS. SALVAGE ALL IDENTIFIED ITEMS FOR REUSE PER OWNER INSTRUCTION
9. REMOVE ALL CEILINGS IN AREA 1 SBHC, U.O.N.
10. CONTRACTOR IS TO COORDINATE DEMOLITION SCHEDULE WITH OPS ASBESTOS ABATEMENT SCHEDULE.
11. OPS TO REMOVE EXISTING FLOOR TILE IN AREA 1 (SBHC) AS PART OF ASBESTOS ABATEMENT; DO NOT INCLUDE IN SCOPE

DEMOLITION KEYED NOTES:


- 1 CONTRACTOR TO REMOVE INTERIOR WALL PRIOR TO ASBESTOS ABATEMENT. CONTRACTOR IS TO TAKE SPECIAL CARE TO NOT DISRUPT THE EXISTING FLOOR TILE, AND CANNOT REMOVE THE BOTTOM PLATE OF INTERIOR WALLS THAT IS ATTACHED TO THE EXISTING FLOOR TILE. OWNER WILL REMOVE EXISTING FLOOR TILE AND BOTTOM PLATE OF INTERIOR WALLS AFTER REMOVAL OF ALL OTHER ITEMS BY CONTRACTOR
- 2 REMOVE EXISTING DOOR AND FRAME COMPLETE. CONTRACTOR TO PROTECT EXISTING SURROUNDING BRICK AND CMU AND EXISTING TERRAZZO FLOOR AS MUCH AS POSSIBLE. USE SALVAGED BRICK TO TOOTH IN AROUND NEW OPENING
- 3 NOT USED
- 4 REMOVE DOOR FRAME AND DOOR COMPLETE
- 5 REMOVE WALLS COVERING EXISTING TRANSOM WINDOWS TO EXPOSE ENTIRE WINDOW
- 6 REMOVE EXISTING CMU WALL COMPLETE. CONTRACTOR TO TAKE SPECIAL CARE TO PROTECT EXISTING BRICK COLUMNS, CONCRETE BEAMS, AND TERRAZZO FLOOR AS MUCH AS POSSIBLE
- 7 REMOVE DOOR ONLY; FRAME TO REMAIN
- 8 REMOVE EXISTING COUNTER COIL DOOR AND ALL ASSOCIATED PARTS. SALVAGE AND STORE FOR REUSE AT NEW TICKET BOOTH; SEE PLAN FOR LOCATION
- 9 REMOVE EXISTING TERRAZZO BENCHES AND BASES. PROTECT SURROUNDING TERRAZZO FLOORING AS MUCH AS POSSIBLE; MINIMIZE SURROUNDING TERRAZZO FLOORING REMOVAL AT BASE AS MUCH AS POSSIBLE. PREP FLOOR FOR A SMOOTH TRANSITION FROM EXISTING TERRAZZO FLOORING TO INFILL OF NEW TERRAZZO FLOORING; SEE ALT. NO. 1
- 10 SAWCUT CMU WALLS FOR MECHANICAL OPENING. PATCH WALL TIGHT TO DUCTWORK. COORDINATE WITH MECHANICAL
- 11 REMOVE AND SALVAGE EXISTING SALES COUNTER MILLWORK AND ALL ASSOCIATED COMPONENTS FOR REINSTALLATION IN BOOKSTORE. REMOVE EXISTING PLASTIC LAMINATE TOP; PREP FOR NEW SOLID SURFACE TOP. SEE PLAN FOR LOCATION
- 12 REMOVE ALL EXISTING FLOOR CERAMIC TILE. PREP FOR LEVEL SURFACE
- 13 REMOVE ALL SHOWER FIXTURES AND CAP ALL ASSOCIATED PIPING AS REQUIRED BY CODE. NO NEW FIXTURE TO BE INSTALLED
- 14 SAWCUT CMU FOR NEW DOOR OPENING
- 15 CUT HOLE IN CONCRETE FLOOR FOR MECHANICAL OPENING. PATCH FLOOR TIGHT TO DUCTWORK. COORDINATE WITH MECHANICAL
- 16 REMOVE CONCRETE CURB AND PARTIAL HEIGHT CMU WALL COMPLETE; PREP FOR LEVEL FLOOR
- 17 REMOVE EXISTING COUNTER AND ALL ASSOCIATED PARTS. REMOVE WALL BELOW COUNTER TO ALLOW FOR NEW FULL HEIGHT COIL DOOR. CONTRACTOR TO PROTECT SURROUNDING BRICK AS MUCH AS POSSIBLE. USE SALVAGED BRICK TO TOOTH IN AROUND NEW OPENING
- 18 REMOVE EXISTING BRICK AND CMU WALL FOR NEW OPENING. CONTRACTOR TO PROTECT SURROUNDING BRICK AS MUCH AS POSSIBLE. USE SALVAGED BRICK TO TOOTH IN AROUND NEW OPENING
- 19 SAWCUT EXISTING TERRAZZO/CONCRETE FLOOR AS REQ'D FOR PLUMBING WORK; SEE MECH
- 20 DEMO EXISTING ACOUSTIC PLASTER CEILING AS NECESSARY FOR MECHANICAL DUCTWORK INSTALLATION. SEE MECH

**SCHOOL-BASED HEALTH CENTER:
BRYAN HIGH SCHOOL**

4700 Giles Road
Omaha, NE 68157



SECOND FLOOR




FIRST FLOOR

Bryan High School

**ALLEY POYNER
MACCHETTO
ARCHITECTURE** 1516 Cuming Street
Omaha, NE 68102
Ph: 402.341.1544
Fx: 402.341.4735
alleepoyner.com

STRUCTURAL ENGINEER
PERFORMANCE ENGINEERING
4940 N. 118TH STREET, SUITE 200
OMAHA, NE 68164
(402) 255-3825 / FAX: (402) 343-3961

MECHANICAL AND ELECTRICAL ENGINEERS
MORRISSEY ENGINEERING
4940 N. 118TH STREET
OMAHA, NE 68164
(402) 491-4144 / FAX: (402) 491-4146



ADDENDUM #1 05/07/2013

REVISION DATE


PROJECT NUMBER: 12085

DATE: 05/03/2013

COPYRIGHT © 2013
ALLEY POYNER MACCHETTO ARCHITECTURE, P.C.

PARTIAL FIRST FLOOR DEMO PLAN;
PARTIAL SECOND FLOOR DEMO PLAN

AD1.1.1



E1 PARTIAL FIRST FLOOR PLAN - MENS LOCKER ROOM

AD1.1.2 SCALE: 1/8" = 1'-0"

DEMOLITION GENERAL NOTES:


1. THE INTENT OF THESE DEMOLITION DRAWINGS IS TO DEFINE A GENERAL SCOPE OF DEMOLITION WORK. THESE DRAWINGS MAY NOT IDENTIFY EVERY ITEM TO BE REMOVED. THE CONTRACTOR IS RESPONSIBLE FOR DETERMINING ALL ITEMS WHICH MUST BE REMOVED TO FACILITATE NEW CONSTRUCTION
2. **NO DEMO OR CONSTRUCTION WORK** TO BE PERFORMED IN HATCHED AREA
3. ITEMS DRAWN BOLD AND DASHED ARE TO BE REMOVED. REFER TO KEYED NOTES FOR SPECIFIC ITEMS
4. REMOVE ALL ABANDONED PIPING, ELECTRICAL CONDUIT, MISCELLANEOUS HANGERS, MISCELLANEOUS DUCTWORK, AND ALL OTHER ABANDONED ITEMS UNLESS OTHERWISE NOTED
5. CONTRACTOR TO SHORE EXISTING STRUCTURE AS NEEDED
6. IDENTIFY EXISTING AREAS OF STRUCTURALLY UNSOUND FLOOR AND FRAMING ELEMENTS FOUND DURING DEMOLITION PROCESS. ADVISE ARCHITECT OF CONDITION
7. COORDINATE ALL REMOVAL AND LOCATION OF WALL AND FLOOR PENETRATIONS WITH NEW CONSTRUCTION
8. DISPOSE OF ALL ITEMS IN ACCORDANCE WITH ALL APPLICABLE REQUIREMENTS. SALVAGE ALL IDENTIFIED ITEMS FOR REUSE PER OWNER INSTRUCTION
9. REMOVE ALL CEILINGS IN AREA 1 SBHC, U.O.N.
10. CONTRACTOR IS TO COORDINATE DEMOLITION SCHEDULE WITH OPS ASBESTOS ABATEMENT SCHEDULE.
11. OPS TO REMOVE EXISTING FLOOR TILE IN AREA 1 (SBHC) AS PART OF ASBESTOS ABATEMENT; DO NOT INCLUDE IN SCOPE

DEMOLITION KEYED NOTES:

- 1 CONTRACTOR TO REMOVE INTERIOR WALL PRIOR TO ASBESTOS ABATEMENT. CONTRACTOR IS TO TAKE SPECIAL CARE TO NOT DISRUPT THE EXISTING FLOOR TILE, AND CANNOT REMOVE THE BOTTOM PLATE OF INTERIOR WALLS THAT IS ATTACHED TO THE EXISTING FLOOR TILE. OWNER WILL REMOVE EXISTING FLOOR TILE AND BOTTOM PLATE OF INTERIOR WALLS AFTER REMOVAL OF ALL OTHER ITEMS BY CONTRACTOR
- 2 REMOVE EXISTING DOOR AND FRAME COMPLETE. CONTRACTOR TO PROTECT EXISTING SURROUNDING BRICK AND CMU AND EXISTING TERRAZZO FLOOR AS MUCH AS POSSIBLE. USE SALVAGED BRICK TO TOOTH IN AROUND NEW OPENING
- 3 NOT USED
- 4 REMOVE DOOR FRAME AND DOOR COMPLETE
- 5 REMOVE WALLS COVERING EXISTING TRANSOM WINDOWS TO EXPOSE ENTIRE WINDOW
- 6 REMOVE EXISTING CMU WALL COMPLETE. CONTRACTOR TO TAKE SPECIAL CARE TO PROTECT EXISTING BRICK COLUMNS, CONCRETE BEAMS, AND TERRAZZO FLOOR AS MUCH AS POSSIBLE
- 7 REMOVE DOOR ONLY; FRAME TO REMAIN
- 8 REMOVE EXISTING COUNTER COIL DOOR AND ALL ASSOCIATED PARTS. SALVAGE AND STORE FOR REUSE AT NEW TICKET BOOTH; SEE PLAN FOR LOCATION
- 9 REMOVE EXISTING TERRAZZO BENCHES AND BASES. PROTECT SURROUNDING TERRAZZO FLOORING AS MUCH AS POSSIBLE; MINIMIZE SURROUNDING TERRAZZO FLOORING REMOVAL AT BASE AS MUCH AS POSSIBLE. PREP FLOOR FOR A SMOOTH TRANSITION FROM EXISTING TERRAZZO FLOORING TO INFILL OF NEW TERRAZZO FLOORING; SEE ALT. NO. 1
- 10 SAWCUT CMU WALLS FOR MECHANICAL OPENING. PATCH WALL TIGHT TO DUCTWORK. COORDINATE WITH MECHANICAL
- 11 REMOVE AND SALVAGE EXISTING SALES COUNTER MILLWORK AND ALL ASSOCIATED COMPONENTS FOR REINSTALLATION IN BOOKSTORE. REMOVE EXISTING PLASTIC LAMINATE TOP; PREP FOR NEW SOLID SURFACE TOP. SEE PLAN FOR LOCATION
- 12 REMOVE ALL EXISTING FLOOR CERAMIC TILE. PREP FOR LEVEL SURFACE
- 13 REMOVE ALL SHOWER FIXTURES AND CAP ALL ASSOCIATED PIPING AS REQUIRED BY CODE. NO NEW FIXTURE TO BE INSTALLED
- 14 SAWCUT CMU FOR NEW DOOR OPENING
- 15 CUT HOLE IN CONCRETE FLOOR FOR MECHANICAL OPENING. PATCH FLOOR TIGHT TO DUCTWORK. COORDINATE WITH MECHANICAL
- 16 REMOVE CONCRETE CURB AND PARTIAL HEIGHT CMU WALL COMPLETE; PREP FOR LEVEL FLOOR
- 17 REMOVE EXISTING COUNTER AND ALL ASSOCIATED PARTS. REMOVE WALL BELOW COUNTER TO ALLOW FOR NEW FULL HEIGHT COIL DOOR. CONTRACTOR TO PROTECT SURROUNDING BRICK AS MUCH AS POSSIBLE. USE SALVAGED BRICK TO TOOTH IN AROUND NEW OPENING
- 18 REMOVE EXISTING BRICK AND CMU WALL FOR NEW OPENING. CONTRACTOR TO PROTECT SURROUNDING BRICK AS MUCH AS POSSIBLE. USE SALVAGED BRICK TO TOOTH IN AROUND NEW OPENING
- 19 SAWCUT EXISTING TERRAZZO/CONCRETE FLOOR AS REQ'D FOR PLUMBING WORK; SEE MECH
- 20 DEMO EXISTING ACOUSTIC PLASTER CEILING AS NECESSARY FOR MECHANICAL DUCTWORK INSTALLATION. SEE MECH

**SCHOOL-BASED HEALTH CENTER:
BRYAN HIGH SCHOOL**


4700 Giles Road
Omaha, NE 68157



**ALLEY•POYNER
MACCHIETTO
ARCHITECTURE** 1516 Cuming Street
Omaha, NE 68102
Ph: 402.341.1544
Fx: 402.341.4735
alleepoyner.com

STRUCTURAL ENGINEER
PERFORMANCE ENGINEERING
4940 N. 118TH STREET, SUITE 200
OMAHA, NE 68144
(402) 255-3825 / FAX: (402) 343-3961

MECHANICAL AND ELECTRICAL ENGINEERS
MORRISSEY ENGINEERING
4940 N. 118TH STREET
OMAHA, NE 68144
(402) 491-4144 / FAX: (402) 491-4146



ADDENDUM #1 05/07/2013

REVISION _____ DATE _____


PROJECT NUMBER: 12085

DATE: 05/03/2013

COPYRIGHT © 2013
ALLEY•POYNER MACCHIETTO ARCHITECTURE, P.C.


PARTIAL FIRST FLOOR DEMO PLAN -
MENS LOCKER ROOM

AD1.1.2



M1 PARTIAL SECOND FLOOR PLAN

A1.1.1 SCALE: 1/8" = 1'-0"



M8 AREAS 1 & 2: PARTIAL FIRST FLOOR PLAN

A1.1.1 SCALE: 1/8" = 1'-0"

GENERAL NOTES:


1. SEE G1.0 FOR GENERAL BUILDING NOTES
2. VERIFY ALL CONDITIONS PRIOR TO THE START OF CONSTRUCTION. REPORT ANY DISCREPANCIES TO THE ARCHITECT IMMEDIATELY.
3. ITEMS SHOWN IN FULL TONE ARE NEW CONSTRUCTION. ITEMS SHOWN IN HALFTONE ARE EXISTING AND TO REMAIN.
4. CONTRACTOR TO WORK WITH OPS ON PHASING PROJECT AROUND OPS ENVIRONMENTAL ABATEMENT
5. ALL STUD WALLS ARE DIMENSIONED FROM FACE OF FINISH TO FACE OF FINISH. APPLIED FINISHES SUCH AS CERAMIC TILE ARE NOT INCLUDED AS PART OF THE WALL THICKNESS. HOLD AND CLEAR DIMENSIONS ARE TO FINISHED FACE.
6. ALL NEW INTERIOR WALLS ARE TYPE P4 UNLESS NOTED OTHERWISE.
7. ALL GYP. BD. JOINTS SHALL BE TAPED AND FINISHED FOR FULL HEIGHT OF WALL.
8. FURNITURE AND EQUIPMENT IS N.I.C. AND IS SHOWN FOR COORDINATION PURPOSES ONLY.
9. SEE INTERIOR ELEVATIONS FOR CASEWORK DIMENSIONS. PROVIDE BLOCKING AS REQUIRED FOR SECURING ALL ELEMENTS.
10. ALL FRAMED WALLS TO REST ON SILL SEALER. SEE WALL TYPES FOR ADDITIONAL REQUIREMENTS.
11. PROVIDE TRANSITION STRIP BETWEEN ALL CHANGES IN FLOOR MATERIAL. SEE FLOOR PLANS AND ROOM FINISH SCHEDULE FOR MATERIAL CHANGES.
12. SEE SHEET A6.1 FOR GLAZING AND DOOR TYPES
13. SEE A5.1 FOR TOILET ACCESSORY LOCATIONS AND SCHEDULE

KEYED NOTES:


1. INSTALL CORNERGUARD (CG-1) AT OUTSIDE CORNER
2. PROVIDE 12"H WALL PROTECTION RUB STRIP (WP-1) ENTIRE LENGTH OF WALL. SEE ELEVATIONS
3. EXISTING TERRAZZO FLOOR PATTERN
4. PROVIDE MECHANICAL PLUMBING CHASE. COORDINATE WITH MECHANICAL
5. CENTER WALL ON EXISTING COLUMN/BEAM
6. CENTER WALL ON EXISTING WINDOW MULLION; SEE F15/A5.3
7. PROVIDE NEW FULL-HEIGHT COIL DOOR AT EXISTING COUNTER HEIGHT COIL DOOR LOCATION. SEE SPEC. SALVAGE REMOVED BRICK TO TOOTH BRICK BACK INTO NEW OPENING TO PROVIDE A SMOOTH UNIFORM TRANSITION AT THE NEW OPENING
8. SURFACE MOUNTED FIRE EXTINGUISHER N.I.C.; PROVIDE BLOCKING. FIRE EXTINGUISHER PROVIDED BY OPS
9. EXISTING LECTURE ROOM TIERED SEATING
10. EXISTING COMMONS "PIT"
11. ALIGN EDGE OF WALL WITH EDGE OF PRECAST AT BULKHEAD ABOVE. SEE M7/A5.3 FOR LOCATION
12. SEE ALT. NO. 1. INFILL REMOVED BENCH LOCATIONS WITH SIMILAR TERRAZZO; PROVIDE A SMOOTH TRANSITION. COLOR TBD
13. INFILL DOOR OPENINGS WITH GWB WALL; CENTER WALL ON EXISTING BRICK/CMU WALL. INSTALL ACOUSTICAL CARPET WITH WOOD FRAME ON CORRIDOR 100A SIDE TO MATCH EXISTING COMMONS ACOUSTICAL CARPET AND FRAMES
14. PARTIAL HEIGHT WALL; ALIGN T.O. NEW PARTIAL HEIGHT WALL WITH BOTTOM OF EXISTING WINDOW SILL
15. INSTALL WF-1 VINYL FILM FULL HEIGHT AND WIDTH OF WINDOW
16. INFILL OPENING TO MATCH ADJACENT EXISTING MATERIALS, FINISHES, AND COLORS
17. NEW DOOR AND FRAME; SEE SCHEDULE
18. EXISTING TERRAZZO TO REMAIN EXPOSED IN THIS AREA. SEE FINISH SCHEDULE
19. LEVEL FLOOR WITH CONCRETE-BASED SELF LEVELING COMPOUND. ENSURE A SMOOTH TRANSITION FROM EXISTING CONCRETE FLOOR IN HALL 113 INTO TEAM ROOM 112
20. NOT USED
21. MECHANICAL SHAFT TO BE TIGHT TO DUCTWORK; COORDINATE WITH MECHANICAL. SEE FINISH SCHEDULE FOR FINISHES OF EXTERIOR OF SHAFT
22. BACK WALL LOCATION DETERMINED BY 6'-8" CEILING CLEARANCE. SEE ELEVATIONS ON A5.1
23. MODIFY EXISTING BOOKSTORE SALES COUNTER MILLWORK AND INSTALL AT THIS LOCATION. REPAIR AND REFINISH WOOD TO MATCH WD DOOR STAIN. INSTALL NEW SOLID SURFACE TOP SS-2. MAXIMIZE EXISTING STORAGE UNITS AT BACK OF COUNTER. INFILL CABINETRY AS NEEDED TO FIT OPENING
24. INSTALL CG-2 AT OUTSIDE CORNER. SEE DETAIL J15/A5.3
25. TACKABLE WALLCOVERING (WC-1 OR WC-2) ON GWB. SEE ELEVATIONS AND DETAILS
26. ALIGN OUTSIDE EDGE OF DOOR FRAME WITH EDGE OF TERRAZZO FLOORING ACCENT STRIPE AS SHOWN
27. INFILL FLOOR AT SAW CUT AREAS TO MAKE LEVEL FLOOR FOR NEW FLOOR FINISH

**SCHOOL-BASED HEALTH CENTER:
BRYAN HIGH SCHOOL**

4700 Giles Road
Omaha, NE 68157



SECOND FLOOR




FIRST FLOOR

Bryan High School

**ALLEY•POYNER
MACCHIETTO
ARCHITECTURE** 1516 Cuming Street
Omaha, NE 68102
Ph: 402.341.1544
Fx: 402.341.4735
alleepoyner.com

STRUCTURAL ENGINEER
PERFORMANCE ENGINEERING
4940 N. 118TH STREET, SUITE 200
OMAHA, NE 68164
(402) 255-3825 / FAX: (402) 343-3961

MECHANICAL AND ELECTRICAL ENGINEERS
MORRISSEY ENGINEERING
4940 N. 118TH STREET
OMAHA, NE 68164
(402) 491-4144 / FAX: (402) 491-4146



ADDENDUM #1 05/07/2013

REVISION DATE


PROJECT NUMBER: 12085

DATE: 05/03/2013

COPYRIGHT © 2013
ALLEY•POYNER MACCHIETTO ARCHITECTURE, P.C.

PARTIAL FIRST FLOOR PLAN;
PARTIAL SECOND FLOOR PLAN

A1.1.1




E1 AREA 3: PARTIAL FIRST FLOOR PLAN - MENS LOCKER ROOM

A1.1.2 SCALE: 1/8" = 1'-0"



H1 NOT USED

A1.1.2 SCALE:



M1 TYPICAL DESK ENLARGED PLAN

A1.1.2 SCALE: 1" = 1'-0"

M5 AREA 1: ENLARGED FIRST FLOOR PLAN - SCHOOL BASED HEALTH CENTER (SBHC)

A1.1.2 SCALE: 1/4" = 1'-0"

GENERAL NOTES:


1. SEE G1.0 FOR GENERAL BUILDING NOTES
2. VERIFY ALL CONDITIONS PRIOR TO THE START OF CONSTRUCTION. REPORT ANY DISCREPANCIES TO THE ARCHITECT IMMEDIATELY.
3. ITEMS SHOWN IN FULL TONE ARE NEW CONSTRUCTION. ITEMS SHOWN IN HALFTONE ARE EXISTING AND TO REMAIN.
4. CONTRACTOR TO WORK WITH OPS ON PHASING PROJECT AROUND OPS ENVIRONMENTAL ABATEMENT
5. ALL STUD WALLS ARE DIMENSIONED FROM FACE OF FINISH TO FACE OF FINISH. APPLIED FINISHES SUCH AS CERAMIC TILE ARE NOT INCLUDED AS PART OF THE WALL THICKNESS. HOLD AND CLEAR DIMENSIONS ARE TO FINISHED FACE.
6. ALL NEW INTERIOR WALLS ARE TYPE P4 UNLESS NOTED OTHERWISE.
7. ALL GYP. BD. JOINTS SHALL BE TAPED AND FINISHED FOR FULL HEIGHT OF WALL.
8. FURNITURE AND EQUIPMENT IS N.I.C. AND IS SHOWN FOR COORDINATION PURPOSES ONLY.
9. SEE INTERIOR ELEVATIONS FOR CASEWORK DIMENSIONS. PROVIDE BLOCKING AS REQUIRED FOR SECURING ALL ELEMENTS.
10. ALL FRAMED WALLS TO REST ON SILL SEALER. SEE WALL TYPES FOR ADDITIONAL REQUIREMENTS.
11. PROVIDE TRANSITION STRIP BETWEEN ALL CHANGES IN FLOOR MATERIAL. SEE FLOOR PLANS AND ROOM FINISH SCHEDULE FOR MATERIAL CHANGES.
12. SEE SHEET A6.1 FOR GLAZING AND DOOR TYPES
13. SEE A5.1 FOR TOILET ACCESSORY LOCATIONS AND SCHEDULE

KEYED NOTES:

1. INSTALL CORNERGUARD (CG-1) AT OUTSIDE CORNER
2. PROVIDE 12"H WALL PROTECTION RUB STRIP (WP-1) ENTIRE LENGTH OF WALL. SEE ELEVATIONS
3. EXISTING TERRAZZO FLOOR PATTERN
4. PROVIDE MECHANICAL PLUMBING CHASE. COORDINATE WITH MECHANICAL
5. CENTER WALL ON EXISTING COLUMN/BEAM
6. CENTER WALL ON EXISTING WINDOW MULLION; SEE F15/A5.3
7. PROVIDE NEW FULL-HEIGHT COIL DOOR AT EXISTING COUNTER HEIGHT COIL DOOR LOCATION. SEE SPEC. SALVAGE REMOVED BRICK TO TOOTH BRICK BACK INTO NEW OPENING TO PROVIDE A SMOOTH UNIFORM TRANSITION AT THE NEW OPENING
8. SURFACE MOUNTED FIRE EXTINGUISHER N.I.C.; PROVIDE BLOCKING. FIRE EXTINGUISHER PROVIDED BY OPS
9. EXISTING LECTURE ROOM TIERED SEATING
10. EXISTING COMMONS "PIT"
11. ALIGN EDGE OF WALL WITH EDGE OF PRECAST AT BULKHEAD ABOVE. SEE M7/A5.3 FOR LOCATION
12. SEE ALT. NO. 1. INFILL REMOVED BENCH LOCATIONS WITH SIMILAR TERRAZZO; PROVIDE A SMOOTH TRANSITION. COLOR TBD
13. INFILL DOOR OPENINGS WITH GWB WALL; CENTER WALL ON EXISTING BRICK/CMU WALL. INSTALL ACOUSTICAL CARPET WITH WOOD FRAME ON CORRIDOR 100A SIDE TO MATCH EXISTING COMMONS ACOUSTICAL CARPET AND FRAMES
14. PARTIAL HEIGHT WALL; ALIGN T.O. NEW PARTIAL HEIGHT WALL WITH BOTTOM OF EXISTING WINDOW SILL
15. INSTALL WF-1 VINYL FILM FULL HEIGHT AND WIDTH OF WINDOW
16. INFILL OPENING TO MATCH ADJACENT EXISTING MATERIALS, FINISHES, AND COLORS
17. NEW DOOR AND FRAME; SEE SCHEDULE
18. EXISTING TERRAZZO TO REMAIN EXPOSED IN THIS AREA. SEE FINISH SCHEDULE
19. LEVEL FLOOR WITH CONCRETE-BASED SELF LEVELING COMPOUND. ENSURE A SMOOTH TRANSITION FROM EXISTING CONCRETE FLOOR IN HALL 113 INTO TEAM ROOM 112
20. NOT USED
21. MECHANICAL SHAFT TO BE TIGHT TO DUCTWORK; COORDINATE WITH MECHANICAL. SEE FINISH SCHEDULE FOR FINISHES OF EXTERIOR OF SHAFT
22. BACK WALL LOCATION DETERMINED BY 6'-8" CEILING CLEARANCE. SEE ELEVATIONS ON A5.1
23. MODIFY EXISTING BOOKSTORE SALES COUNTER MILLWORK AND INSTALL AT THIS LOCATION. REPAIR AND REFINISH WOOD TO MATCH WD DOOR STAIN. INSTALL NEW SOLID SURFACE TOP SS-2. MAXIMIZE EXISTING STORAGE UNITS AT BACK OF COUNTER. INFILL CABINETRY AS NEEDED TO FIT OPENING
24. INSTALL CG-2 AT OUTSIDE CORNER. SEE DETAIL J15/A5.3
25. TACKABLE WALLCOVERING (WC-1 OR WC-2) ON GWB. SEE ELEVATIONS AND DETAILS
26. ALIGN OUTSIDE EDGE OF DOOR FRAME WITH EDGE OF TERRAZZO FLOORING ACCENT STRIPE AS SHOWN
27. INFILL FLOOR AT SAW CUT AREAS TO MAKE LEVEL FLOOR FOR NEW FLOOR FINISH

SCHOOL-BASED HEALTH CENTER: BRYAN HIGH SCHOOL


4700 Giles Road
Omaha, NE 68157



ALLEY•POYNER MACCHIETTO ARCHITECTURE
1516 Cuming Street
Omaha, NE 68102
Ph: 402.341.1544
F: 402.341.4735
alleepoyner.com

STRUCTURAL ENGINEER
PERFORMANCE ENGINEERING
4940 N. 118TH STREET, SUITE 200
OMAHA, NE 68164
(402) 255-3825 / FAX: (402) 343-3961

MECHANICAL AND ELECTRICAL ENGINEERS
MORRISSEY ENGINEERING
4940 N. 118TH STREET
OMAHA, NE 68164
(402) 491-4144 / FAX: (402) 491-4146



ADDENDUM #1 05/07/2013

REVISION	DATE
PROJECT NUMBER: 12085	
DATE: 05/03/2013	


COPYRIGHT © 2013 ALLEY•POYNER MACCHIETTO ARCHITECTURE, P.C.

PARTIAL FIRST FLOOR PLAN - MENS LOCKER ROOM; ENLARGED FIRST FLOOR PLAN - SBHC


A1.1.2

SCHOOL-BASED HEALTH CENTER: BRYAN HIGH SCHOOL

4700 Giles Road
Omaha, NE 68157



SECOND FLOOR



FIRST FLOOR

Bryan High School

ALLEY•POYNER
MACCHETTO
ARCHITECTURE 1516 Cuming Street
Omaha, NE 68102
Ph: 402.341.1544
Fx: 402.341.4735
alleepoyner.com

STRUCTURAL ENGINEER
PERFORMANCE ENGINEERING
4940 N. 118TH STREET, SUITE 200
OMAHA, NE 68164
(402) 255-3825 FAX: (402) 343-3961

MECHANICAL AND ELECTRICAL ENGINEERS
MORRISSEY ENGINEERING
4940 N. 118TH STREET
OMAHA, NE 68164
(402) 491-4144 FAX: (402) 491-4146



ADDENDUM #1 05/07/2013

REVISION DATE


PROJECT NUMBER: 12085

DATE: 05/03/2013

COPYRIGHT © 2013
ALLEY•POYNER MACCHETTO ARCHITECTURE, P.C.


INTERIOR ELEVATIONS

A5.1




C1 CORRIDOR 100A ELEVATION

A5.1 SCALE: 1/4" = 1'-0"




C8 LOBBY 100B ELEVATION

A5.1 SCALE: 1/4" = 1'-0"




C11 NURSE STATION 101 ELEVATION

A5.1 SCALE: 1/4" = 1'-0"




C14 LAB/REGISTRATION 102 ELEVATIONS

A5.1 SCALE: 1/4" = 1'-0"




F1 RESTROOM 106 ELEVATIONS

A5.1 SCALE: 1/4" = 1'-0"




F8 TOILET ACCESSORIES

A5.1 SCALE: 1/4" = 1'-0"




F11 EXAM ROOM 103 ELEVATIONS (MIRROR AT EXAM ROOM 105)

A5.1 SCALE: 1/4" = 1'-0"




J1 COMMONS 111 ELEVATION - LOOKING NORTH

A5.1 SCALE: 1/4" = 1'-0"




J14 OFFICE 107 ELEVATION (OFFICES 108 & 109 SIM.)

A5.1 SCALE: 1/4" = 1'-0"



M1 COMMONS 111 ELEVATION - LOOKING WEST

A5.1 SCALE: 1/4" = 1'-0"



M10 BOOKSTORE 110 ELEVATIONS

A5.1 SCALE: 1/4" = 1'-0"

NOTE: MIRROR ELEVATION 'B' FOR ELEVATION 'C'

SECTION 006000 - INVITATION TO BID

Project: SBHC-Bryan High School
4700 Giles Road
Omaha, Nebraska 68157

Owner: One World Community Health Center, Inc.
4910 South 30th Street
Omaha, NE 68107

Architect: Alley Poyner Macchietto Architecture P.C.
1516 Cuming Street
Omaha, Nebraska 68102

Alley Poyner Macchietto Architecture P.C. will accept bids on behalf of the Owner from qualified General Contractors for renovation of the existing building located at 4700 Giles Road, Omaha, NE 68134 until 2:00 PM CST, Tuesday, May 21, 2013 at the office of Alley Poyner Macchietto Architecture, 1516 Cuming Street, Omaha, NE, 68102. The contractor shall submit bids in 9 x 12 envelopes with "**PROPOSAL, SBHC- Bryan HS**" and the name of the bidder written clearly on its front. Bids will be opened privately and reviewed before accepted. Bids received after this time will not be accepted.

All contractors submitting bids for the work are representing that they have carefully examined the site and building and are familiar with all conditions that may affect the Work under the Contract. A pre-bid walk-thru of the existing facility is scheduled for Thursday May 9, 2013 at 10:00 am.

Bidding documents may be examined at any of the following locations:

A&D Technical Supply
4320 South 89th Street
Omaha, NE 68127
(402) 592-4950 FAX: (402) 592-9302 <http://www.adtechsupply.com>

Lincoln Builders Bureau
5910 So. 58th Street, Suite "C"
Lincoln, Nebraska 68516
(402) 421-8332 FAX: (402) 421-8334

Omaha Builder's Exchange
4255 So. 94th Street
Omaha, Nebraska 68127
(402) 593-6908 FAX: (402) 593-6912

Contractor Development Services.
1313 Cuming Street Suite 200
Omaha, Ne 68102
402-399-9090

McGraw-Hill Construction
2507 Ingersoll Avenue
Des Moines, IA 50312
Phone: (513) 763-3628 Fax: (800) 768-5594

No Bidder may withdraw his Proposal for a period of forty-five (45) days after date set for opening bids.

Contractors may obtain drawings and specifications for the work from the office A & D Tech Supply, 4320 South 89th Street, Omaha, NE 68127, (402) 592-4950, A & D Technical Supply in Lincoln, NE or order through their Virtual Plan Room at www.adtechsupply.com. A refundable deposit of \$50.00 or a Builder's Card will be required. Make deposit checks payable to Alley Poyner Macchietto Architecture P.C. Checks for the Shipping and Handling should be made

out to A & D Tech Supply. Documents must be returned complete and in “like new” condition to obtain a refund. **Plans must be returned no later than one month after bid date. One reminder phone call will be placed before deposit is forfeited.**

The Owner reserves the right to reject any or all bids, and to waive any formalities or irregularities in bidding.

The successful bidder shall be required to furnish a Performance Bond and a Labor and Materials Bond in the amount of 100% the bid submitted and a list of Subcontractors within 3 days of being awarded the project.

The proposed start date of construction is June 3, 2013.