ADDENDUM NO. 3

Project: NDOR Central Building Penthouse Re-Roof
Project No.: AFE I-036

Issued: July 31, 2013

Bid Date: August 1, 2013, 3:30 p.m. CDT

This Addendum is issued to all known plan holders before receipt of proposals.

The following shall be included with, and considered a part of, the original contract documents to the same extent as if they were included therein, for the construction of the above mentioned project. The Project Manual and Drawings shall be modified or revised as herein described. Where at variance with the original work, this Addendum shall have precedence.

This Addendum modifies the original Bidding Documents. The Bidder must acknowledge receipt of this Addendum in the space provided on the Proposal Form. Failure to do so may subject bidder to disqualification.

ARCHITECTURAL ADDENDA ITEMS:

AD3.1. Clarification to Specifications: Section 07 53 00, Elastomeric Membrane Roofing, Section 2.2.B:

Item 2.2.B3: Top layer of insulation shall be adhered, as specified.

Item 2.2.B4: Cover board shall be adhered.

END OF ADDENDUM NO. 3

209 South 9th Street **402.475.1787 Tel.**
Lincoln, Nebraska 68508 **402.475.1800 Fax**