



ARCHITECTURE • ENGINEERING • INTERIOR DESIGN

ADDENDUM

PROJECT: Cherry County Hospital
Patient Wing - Toilet Room Renovation
Valentine, Nebraska

ADDENDUM NUMBER

AD-5

ISSUED BY:

Greg Smith, Architect
Bryce Johnson, Mechanical Engineer
Jon Dalton, Electrical Engineer

PROJECT #: 11-0148

DATE ISSUED: Friday, August 2, 2013

This addendum is issued by the Architect to all known bidders before receipt of proposals, for the purpose of explaining, interpreting, or modifying the original plans and specifications. When enumerated by the bidder upon the proposal sheet, the information or instructions given hereon will be equally binding upon all parties as if included in the original plans and specifications.

BIDDER MUST ENTER THE NUMBER OF THIS ADDENDUM ON HIS PROPOSAL SHEET

THE FOLLOWING ITEMS ARE APPLICABLE TO THE DRAWINGS:

AD-5, ITEM 1:

In reference to Sheet A102, add the following to General Notes: "5. Where mechanical or electrical demolition occurs at existing wall surfaces to remain, contractor to patch and repair to match existing. This includes but not limited to locations where existing bed pan washers are removed.

AD-5, ITEM 2:

In reference to Sheet P-105, as a matter of clarification, for In Building Domestic Water Piping provide Soldered Joints as indicated. Crimped or compression fittings will not be accepted.

AD-5, ITEM 3:

In reference to Sheet E-102, Room 206, leave existing patient lights, conduit, and wire over beds.

AD-5, ITEM 4:

In reference to Sheet E-104, remove Patient Room 206 new bed lights and switching from drawing. Existing bed lights and switching to be re-used. Keynotes 8, 15, and 16 to be removed from Room 206.

END AD-5