

**Sampson Construction Co., Inc.**  
**3730 South 14<sup>th</sup> Street**  
**Lincoln, NE 68502**  
**Phone: (402) 434-5450**  
**FAX: (402) 434-5466**

**Bid Bulletin #04**

PROJECT: Baldwin Filters Distribution Facility (Bid Package #02)  
Kearney, NE

DATE: October 25, 2013

This Bid Bulletin includes items 1-1. Each item shall be fully incorporated into the Bidding/Contract Documents and have the same force and effect as though originally included. Bidders shall acknowledge receipt of this Bid Bulletin on the bid form.

Item 1-1 Attached is Addendum #3 from Davis Design dated 10/25/13

END OF BID BULLETIN #04



ARCHITECTURE • ENGINEERING • INTERIOR DESIGN

## ADDENDUM

PROJECT: Baldwin Filters  
Main Distribution Center  
Bid Package #2 - Electrical  
Kearney, Nebraska

### ADDENDUM NUMBER

AD-3

### ISSUED BY:

Mike Wachal, Coordinating Professional  
Jon Dalton, Electrical Engineer

PROJECT #: 13-0061

DATE ISSUED: Friday, October 25, 2013

*This addendum is issued by the Architect to all known bidders before receipt of proposals, for the purpose of explaining, interpreting, or modifying the original plans and specifications. When enumerated by the bidder upon the proposal sheet, the information or instructions given hereon will be equally binding upon all parties as if included in the original plans and specifications.*  
**BIDDER MUST ENTER THE NUMBER OF THIS ADDENDUM ON HIS PROPOSAL SHEET**

### THE FOLLOWING ITEMS ARE APPLICABLE TO THE SPECIFICATIONS:

#### AD-3, ITEM 1:

In reference to Section 260519 - Low-Voltage Electrical Power Conductors and Cables, Page 260519-3, Article, 3.1, Paragraph B, revise to read as follows:

"B. Feeders: Copper for feeders smaller than **No. 4/0** AWG; copper or aluminum for feeders **No. 4/0** AWG and larger. See feeder schedule on drawings for more information. See feeder schedule and switchboard / power panel schedules on drawings for more information."

END AD-3