



ARCHITECTURE • ENGINEERING • INTERIOR DESIGN

## ADDENDUM

**PROJECT:** University of South Dakota  
Davidson Hall  
Reroof  
Vermillion, South Dakota

### ADDENDUM NUMBER

AD-2

### ISSUED BY:

Matt Metcalf, Architect

**PROJECT #:** 13-0180

**DATE ISSUED:** Tuesday, January 28, 2014

*This addendum is issued by the Architect to all known bidders before receipt of proposals, for the purpose of explaining, interpreting, or modifying the original plans and specifications. When enumerated by the bidder upon the proposal sheet, the information or instructions given hereon will be equally binding upon all parties as if included in the original plans and specifications.*

**BIDDER MUST ENTER THE NUMBER OF THIS ADDENDUM ON HIS PROPOSAL SHEET**

### THE FOLLOWING ITEMS ARE APPLICABLE TO THE SPECIFICATIONS:

#### AD-2, ITEM 1:

Subject to compliance with specifications and review of shop drawings the following manufactures are approved.

<u>Section</u>	<u>Manufacturer</u>
055000 - Metal Fabrications	Precision Ladders, LLC
075323 - EPDM Roofing	Mule Hide Products

#### AD-2, ITEM 2:

In reference to specification Section 05500 - Metal Fabrications. Add paragraph. 2.6.C. as follows:

"C. Aluminum Ladders. Model FLH-\*\*\* by Precision Ladders, LLC.

1. Space siderails as indicated on drawings.
2. Siderails: Continuous, 3 inch x1 inch extruded 6005-T5 aluminum tubing with capped ends where required. Miter corners.
3. Rungs: 2-1/4 inch by 3/4 inch by 1/4 inch extruded 6005-T5 aluminum with deeply serrated top surface.
4. Mill Finish."

### THE FOLLOWING ITEMS ARE APPLICABLE TO THE DRAWINGS:

#### AD-2, ITEM 3:

As a matter of clarification, aluminum ladders in lieu of steel ladders are approved for use.

**END AD-2**