



ARCHITECTURE • ENGINEERING • INTERIOR DESIGN

## ADDENDUM

**PROJECT:** University of South Dakota  
Carpenters Storage  
Roof Modifications  
Vermillion, South Dakota

### ADDENDUM NUMBER

AD-1R

### ISSUED BY:

Matt Metcalf, Architect

**PROJECT #:** 13-0105

**DATE ISSUED:** Thursday, February 13, 2014

*This addendum is issued by the Architect to all known bidders before receipt of proposals, for the purpose of explaining, interpreting, or modifying the original plans and specifications. When enumerated by the bidder upon the proposal sheet, the information or instructions given hereon will be equally binding upon all parties as if included in the original plans and specifications.*  
**BIDDER MUST ENTER THE NUMBER OF THIS ADDENDUM ON HIS PROPOSAL SHEET**

### THE FOLLOWING ITEMS ARE APPLICABLE TO THE DRAWINGS:

**AD-1R, ITEM #:**

In reference to Sheet A-101, change keynote #10 to read "L2x2x3/16" at 24" o.c. max. and at unsupported edges of plywood, cope and weld to C8.

**END AD-1R**