

ADDENDUM



Date: February 19, 2014

Project: Wayne State College
Recreation Center/Carlson Natatorium
Fire-Alarm System Upgrade

To: Bidding Contractors

Project No.: 2013-101

Addendum No.: 2

CC:

CHANGES TO PROJECT MANUAL

Section 28 31 11 – Digital, Addressable Fire-Alarm System

1. 2.03.A.1 – replace with the following: all manual pull stations shall be double-action mechanisms and not single-action mechanisms. They shall have two actions to initiate an alarm, pull-lever type; with integral addressable module arranged to communicate manual-station status (normal, alarm, or trouble) to fire alarm control unit.

CHANGES TO PROJECT DRAWINGS

By: Jason Leu

Date: 2/19/14