



ARCHITECTURE • ENGINEERING • INTERIOR DESIGN

## ADDENDUM

**PROJECT:** Nebraska Department of Correctional Services  
Cornhusker State Industries  
Nebraska State Penitentiary  
Laundry Renovations / Facility Alterations  
Lincoln, Nebraska

### ADDENDUM NUMBER

AD-4

### ISSUED BY:

Mike Wachal, Coordinating Professional  
Greg Smith, Architect

**PROJECT #:** DDI No. 13-0167 / NDCS No. 1305

**DATE ISSUED:** Wednesday, March 19, 2014

*This addendum is issued by the Architect to all known bidders before receipt of proposals, for the purpose of explaining, interpreting, or modifying the original plans and specifications. When enumerated by the bidder upon the proposal sheet, the information or instructions given hereon will be equally binding upon all parties as if included in the original plans and specifications.*

**BIDDER MUST ENTER THE NUMBER OF THIS ADDENDUM ON HIS PROPOSAL SHEET**

### THE FOLLOWING ITEMS ARE GENERAL INFORMATION:

#### AD-4, ITEM 1:

**In reference to Toilet Partitions**, product to be equal to Bradley floor-braced phenolic Series 500.

### THE FOLLOWING ITEMS ARE APPLICABLE TO THE SPECIFICATIONS:

#### AD-4, ITEM 2:

**In reference to Section 012200 - Unit Prices**, please note the following:

As a point of clarification to Unit Cost #1 for the Fencing and Mow strip, the entire fencing and Mow Strip as indicated on the plans and specifications are to be included in the base bid amount. The unit costs that are indicated on the bid form will be used for any additions or subtractions to the scope of work indicated on the bid documents.

As a point of clarification to Unit Cost #2 for the Concrete Apron Paving, the entire paving as indicated on the plans and specifications are to be included in the base bid amount. The unit costs that are indicated on the bid form will be used for any additions or subtractions to the scope of work indicated on the bid documents.

**THE FOLLOWING ITEMS ARE APPLICABLE TO THE DRAWINGS:**

**AD-4, ITEM 3:**

In reference to **Sheet A-202, Detail #8**, regarding the coiling fire door that is indicated to be installed at the elevator opening, it is to be a 90-minute fire-rated coiling shutter door. Overhead Door model 635 or equal.

**AD-4, ITEM 4:**

In reference to **Sheets A-201 and A-202 (Detail #10)**, the Mapes panel indicated does not require the vertical and horizontal joints indicated on the elevation drawing.

**END AD-4**