



DATE ISSUED 14 April 2014

ADDENDUM # 1

ENGINEER Engineering Technologies, Inc.
825 M Street, Suite 200
Lincoln, NE 68508

PROJECT LPS - Park Middle School
-Fire Alarm Replacement

ETI PROJECT # 2013-012

LPS BID # 7791

The Engineer issues this Addendum to all known bidders before receipt of proposals. Bidder shall acknowledge the receipt of this addendum on their proposal sheet and all information contained herein shall become a part of the contract documents.

ADDENDUM:

GENERAL ITEMS – ELECTRICAL

- 1. For clarification, the fire sprinkler system shall remain functioning and the monitoring of the fire sprinkler system by the fire alarm system shall be kept in place during the fire alarm replacement process. Provide all necessary provision to comply with this requirement.
2. For clarification, on Page 00 1113-1, the Pre Bid Conference will be held at the office of Facilities and Maintenance, 800 South 24th Street, Lincoln, Nebraska on April 17, 2014 at 9:00 A.M. CST. Delete the sentence that reads, "Meeting will start at the front entrance area inside of the school at the Administration office."

END OF ADDENDUM