



DATE ISSUED 24 April 2014

ADDENDUM # 2

ENGINEER Engineering Technologies, Inc.
825 M Street, Suite 200
Lincoln, NE 68508

PROJECT LPS - Park Middle School
-Fire Alarm Replacement

ETI PROJECT # 2013-012

LPS BID # 7791

The Engineer issues this Addendum to all known bidders before receipt of proposals. Bidder shall acknowledge the receipt of this addendum on their proposal sheet and all information contained herein shall become a part of the contract documents.

ADDENDUM:

GENERAL ITEMS – ELECTRICAL

- 1. Attached is the Pre-Bid Agenda and Sign-in sheet from the 04-17-14 pre-bid meeting.
2. The following is a list of activities occurring at each school over the summer months:
A. Park Middle School:
i. Park is scheduled to have summer school from May 27 until July 10, from 8am till noon. They will occupy a limited number of rooms. Park also will have a two day work session on June 10 and June 11 in the multipurpose room.
ii. The Fire Marshal has been notified of these activities and is OK with this work taking place when these activities are occurring as long as the fire sprinkler system is operating and being monitored.

END OF ADDENDUM



