



ARCHITECTURE • ENGINEERING • INTERIOR DESIGN

ADDENDUM

PROJECT: University of South Dakota
Davidson Building
UPS
Vermillion, South Dakota

ADDENDUM NUMBER

AD-2

ISSUED BY:

Kori Aaker, Electrical Engineer

PROJECT #: 14-0049

DATE ISSUED: Tuesday, May 20, 2014

This addendum is issued by the Architect to all known bidders before receipt of proposals, for the purpose of explaining, interpreting, or modifying the original plans and specifications. When enumerated by the bidder upon the proposal sheet, the information or instructions given hereon will be equally binding upon all parties as if included in the original plans and specifications.

BIDDER MUST ENTER THE NUMBER OF THIS ADDENDUM ON HIS PROPOSAL SHEET

THE FOLLOWING ITEMS ARE GENERAL INFORMATION:

AD-2, ITEM 1:

Owner furnished equipment totals \$20,855.00.

AD-2, ITEM 2:

In reference to Sheet E-101, Interview Room 101A, change keynote '7' to '18'. Keynote '18' is as follows: "Provide Wiremold #AL3300 series surface raceway of length indicated. Provide #AL3346D device mounting plate with duplex receptacles at locations indicated."

END AD-2