

HAMPTON COMMERCIAL CONSTRUCTION, INC.
3701 Union Drive, Suite 100
Lincoln, NE 68516
www.hampton1.com
(402)489-8858 • (402)489-9287 F A X



HAMPTON
CONSTRUCTION

PROJECT

Name The Career Academy - Bid Package 3

Owner SCC

Bids Due 6/5/2014 Time 2:00 p.m.

ADDENDUM

Number 5

DATE

Issued 6/6/2014

Bid Date Change X Yes No New Bid Date 5/12/14 – CCA 7.1 & 9.1 only

DRAWINGS

Drawings Issued? Yes X No

REMARKS

INCLUDED: 1 page of text from BVH Architects

REMINDER: Bids are to be delivered at:

**LPS Facilities & Maintenance Department
800 S 24th Street
Lincoln, NE 68510**



PROJECT:	The Career Academy	PROJECT NO.	L13414
FROM:	BVH Architects	DATE:	06/05/2014
TO:	Hampton Commercial Construction, Inc.	ADDENDUM	#5

This Addendum is issued by the Architect to all bidders of record prior to receipt of proposals. Bidders shall acknowledge receipt of this addendum by so indicating on the Proposal Form. Failure to do so may subject Bidder to disqualification.

All information and instructions given herein shall become a part of the Contract Documents.

PROJECT MANUAL

1. Section 076200 Part 2.01.A: Copper Flashings shall be 16oz/sf thick.

END OF ADDENDUM