



**ADDENDUM NO. 1**

Project: State of Nebraska – Department of Roads  
District 6 North Platte Re-Roof Project (AFE I-602)

Issued: June 6, 2012

Bid Date: June 12, 2014

This Addendum is issued to all known plan holders before receipt of proposals.

The following shall be included with, and considered a part of, the original contract documents to the same extent as if they were included therein, for the construction of the above mentioned project. The Project Manual and Drawings shall be modified or revised as herein described. Where at variance with the original work, this Addendum shall have precedence.

This Addendum modifies the original Bidding Documents. The Bidder must acknowledge receipt of this Addendum in the space provided on the Proposal Form. Failure to do so may subject bidder to disqualification.

**ARCHITECTURAL ADDENDA ITEMS:**

**AD1.1.** *Specification Section 07 42 13*, Metal Wall and Soffit Panels – Part 2.5 Products, 2.2 Panel Type shall be noted as follows: Firestone ‘Una-Clad’ UC-500 flush panel, 12” wide X 1” high, 22 guage steel wall panels and vented soffit panels with one (1) intermediate stiffening rib. Wall and soft panels shall be G90 hot dipped galvanized Grade A structural quality steel in compliance with ASTM E330-90. Vented panels at soffits, unvented at walls. Colors to be selected by Architect.

**AD1.2.** *Specification Section 07 62 00*, Metal Flashings and Trim – Part 2 Products, 2.2 Sheet Materials: Delete ‘D’ from specifications: “Firestone ‘Una-Clad’ UC-500 Flush Soffit Panels, 12” wide with one (1) intermediate stiffening rib, 032 Aluminum, vented. Same panels, unvented, to be used as wall panels as shown on the drawings.”

**AD1.3.** The following are product substitutions which were received at least seven (7) days prior to receipt of bids and shall be considered approved by the Architect. The manufacturers listed herein will be considered approved for bidding, however the proposed product substitution must meet the intent of the specifications and will be subject to shop submittal approval during construction. Bidders shall include in their bid, any changes required in the Work to accommodate such substitutions.

**Section 07 61 00-2.1**

Sheffield Metals SMI 1.75 SnapLock  
Standing Seam

**Section 07 61 00-2.2**

S-5 ColorGard Snow Guards

**END OF ADDENDUM NO. 1**

