

## addendum

---

**addendum no.** 2

**date:** 6/13/2014

**bid date:** 6/19/2014

**project name:** LPS Security and Technology Ready Facilities Projects - Project C

**project no:** 14062

---

This addendum is hereby made a part of the contract documents to the same extent as if it were originally included therein. Contract documents shall be considered modified or revised as hereinafter described.

### Drawings

1. 143 series drawings: Change flag 23 to be "Pull **one** cable to main office 100 location for **one** button to control doors in access control."
2. 154 series drawings: Change flag 22 to be "Pull **one** cable to main office 100 location for **one** button to control doors in access control."
3. 154 series drawings: Refer to flag note 8, delete reference to "Alternate Bid #154-A". Work shall be included as part of base bid.
4. 162 series drawings: Change flag 22 to be "Pull **one** cable to main office 100 location for **one** button to control doors in access control."
5. 162 series drawings: Refer to flag note 15, delete reference to "Alternate Bid #162-A". Work shall be included as part of base bid.
6. 215 series drawings: Change flag 43 to be "Pull **one** cable to main office B100 location for **one** button to control doors in access control."
7. 302 series drawings: Change flag 40 to be "Pull **one** cable to main office 100 location for **one** button to control doors in access control."
8. Question: Can I get a clarification on detail 8 pg 000.C104 R7? Is it a double duplex or single duplex?

Response: Refer to floor plans for quantity of duplex receptacles (Ex: If floor plans indicate single duplex outlet with reference to R7, provide single duplex receptacle.)

9. Question: On Morley and Pyrtle prints there are notes 8 and 15 respectively that refer to alternate 154-A and 162-A about wall phone rough-ins. The only alternates are 1 and 2 in the spec book. Could you please clarify.

Response: References to alternates 154-A and 162-A deleted as part of this addendum.