

DRAWINGS

1. A1.1 First Floor Plan
 - a. A1
 1. In Women's 109, remove 102800 Soap Dispenser and 102800 Towel and Waste Unit. These will be provided by Owner.
 2. In Men's 110, remove 102800 Soap Dispenser and 102800 Towel and Waste Unit. These will be provided by Owner.
2. G1.0 Cover Sheet
 - a. Sheets Schedule
 1. Under the sheet schedule, remove xM1.2 Roof Mechanical Plan from the list.

END OF ADDENDUM

ADDENDUM



Date: June 12, 2014

Project: Union Bank - Crete

To: Bidding Contractors

Project No.: 2014-030

Addendum No.: 1

CC:

CHANGES TO PROJECT DRAWINGS

1. Sheet E0.1 – Electrical Site Plan

- a. Monument sign: provide (2) 1 ¼" c. from sign underground and stub into Telecom 104.3. Delete the 1" c. shown on plans. Provide pullstrings in all conduits.

2. Sheet E1.1 – First Floor Lighting

- a. Office 116: relocate light switches to adjacent north wall near end of door swing.
- b. Teller 105: connect to circuit A-51. Type 3 fixture at furthest south end of room, middle row shall be a nightlight. Connect switch 'b' to Type 2 pendant lights at counter for control.
- c. Keynote 13: clarification – locate dimming panel where shown on plans.

3. Sheet E2.1 – First Floor Power

- a. Lobby 101: at TV cabinet – mount all devices, j-boxes, etc. at 72" AFF. Verify location with Architect/Owner.
- b. Teller 105: reference detail P18, sheet E4.1 for Drive Through Window information.
- c. Keynote 5: Replace Detail '4' with Detail 'G11'
- d. Office 116: relocate light switches to adjacent north wall near end of door swing.

4. Sheet E3.1 – Electrical & Lighting Schedules

- a. Equipment Connection Schedule: DWH-1, provide a non-fused disconnect in lieu of STE.
- b. Panel A: Ckt A-19, delete GFI breaker.
- c. Luminaire Schedule
 1. Type 9: replace specified fixture with Gotham EVO 41/29 8AR VND 120.
 2. Type 9E: replace specified fixture with Gotham EVO 41/29 8AR VND 120 ELR. Refer to note 7 in 'Notes'.
- d. Lobby 101: at TV cabinet – mount all devices, j-boxes, etc. at 72" AFF. Verify location with Architect/Owner.

5. Sheet E4.1 – Electrical Riser Diagrams

- a. Lighting Control Diagram: Keynote 7 clarification – Dimming control panel shall be LC&D GR2404 ENC SMNE1 GR2404 INT 4NCL IDIM4DV.

By: Jeff Johnson

Date: 6/12/14