

TCEP No.: 530-017-11

ADDENDUM NO. 3

The Architect/ Engineer issues this addendum, applicable to the above named project, to all known Contractors before receipt of proposal.

This addendum includes Items Number 3-1 to 3-2. This addendum item shall be fully incorporated into the Bidding/Contract Documents and have the same force and effect as though originally included.

ELECTRICAL

Drawings

Item 3-1: E1.00 – Concordia Plaza Electrical Site Plans

Refer to Note 15 of the Concordia Plaza Electrical Site Plan Notes. Revise note 15 to read in part as follows: "THE LOWER LEVEL WITH THE OWNER. PANEL TO BE SERVED BY THE NEW 200A/3P BREAKER INSTALLED IN EXISTING MAIN SWITCHBOARD. ROUTE 4-4/0 AND 1-#6 GROUND IN 2" CONDUIT FROM THE NEW BREAKER TO THE NEW PANELBOARD. SEE THE PANELBOARD...".

Refer to Note 18 of the Concordia Plaza Electrical Site Plan Notes. Revise note 15 to read in part as follows: "...CODE COMPLIANT INSTALLATION. COORDINATE THE LOCATION OF THE PEDESTAL WITH THE OWNER AND LANDSCAPE ARCHITECT PRIOR TO INSTALLATION."

Item 3-2: E1.01 – Heartfelt Memorial Electrical Site Plans

Refer to the pedestal reference in Note 1 of the Heartfelt Memorial Electrical Site Plan Notes. Add to the pedestal configuration a photocell mounted to the pedestal for control of the memorial ground mounted fixtures. Photocell to be similar to Intermatic K4123C. Provide necessary connections to lighting circuit.

Refer to the Lighting Fixture Schedule. Provide the Type C fixture nearest the panelboard with a fixture mounted photo control allowing control of remaining fixtures on the circuit.

Refer to the Type C2 light fixture located in the northeast parking area. Circuit the fixture with the Type C fixture to the southeast via underground cable and conduit consistent with that noted on the plans.

END OF ADDENDUM NO. 3