



**ADDENDUM NO. 1**

PAGE 1 of 3

PROJECT:	Ravenna High School – Boiler Replacement	PROJECT NO.	L14132
FROM:	BVH Architects	DATE:	07/03/2014
TO:	All Potential Bidders	ADDENDUM	#1

*This Addendum is issued by the Architect to all bidders of record prior to receipt of proposals. Bidders shall acknowledge receipt of this addendum by so indicating on the Proposal Form. Failure to do so may subject Bidder to disqualification.*

*All information and instructions given herein shall become a part of the Contract Documents.*

GENERAL

1. See the attached Mechanical Addendum Items.
2. See the attached attendance list Pre-Bid meeting on July 1<sup>st</sup> 2014.

END OF ADDENDUM



DATE ISSUED July 2, 2014

ADDENDUM # 1

ENGINEER Engineering Technologies, Inc.  
825 M Street, Suite 200  
Lincoln, NE 68508

PROJECT Ravenna High School - Boiler Replacement

ETI PROJECT # 2014-043

The Architect issues this Addendum to all known bidders before receipt of proposals. Bidder shall acknowledge the receipt of this addendum on their proposal sheet and all information contained herein shall become a part of the contract documents.

**ADDENDUM:**

Attached is the attendance list from the Pre-bid conference at site on July 1, 2014.

**GENERAL ITEMS – MECHANICAL**

1. The Contractor shall boil out the hot water system after all work is complete with a trisodium phosphate solution. The piping system shall then be rinsed until clean. Then the contractor shall work with Water Engineering out of Mead, Nebraska for a solution of softened water and corrosion inhibitors to do final fill of the system.
2. The temperature control contractor shall install a freeze stat at each half of the new hot water coil.
3. The temperature control contractor shall install a temperature sensor at the hot water outlet of the new boiler.
4. The school district will confirm that no asbestos is present and will be responsible for removing any asbestos if it is found during this project.

Attachment

END OF ADDENDUM

# RAVENNA HS BOILER

7/1/14

<u>NAME</u>	<u>FIRM</u>	<u>TELEPHONE</u>	<u>EMAIL</u>
Marty Kasl	ETI	402-476-1273	mkasl@eti-engineers.com
Ron Paul	Rasmussen	402-350-5299	ron.paul@rasmec.com
CHANE McDOWELL	ANDERSON BROS.	(308) 236-6437	chane_mcdowell@andersonbros.co
Zak Krzewski	Anderson Bros	—	—
Todd Schmidt	Engineered Controls	402-434-2110	t.schmidt@engineeredcontrols.com
TIM HEWITT	BAMFORD, INC.	308-440-9003	hewitttim2@gmail.com