

#### **ADDENDUM NO. 4**

The Architect/ Engineer issues this addendum, applicable to the above named project, to all known Contractors before receipt of proposal.

This addendum includes Item Number 4-1. This addendum item shall be fully incorporated into the Bidding/Contract Documents and have the same force and effect as though originally included.

The Bidder shall acknowledge receipt of this Addendum No. 4 on the Bid Proposal Form in the place provided.

#### **ELECTRICAL**

##### **Item 4-1: Sheets E2.1.5, E2.1.6, E2.1.7, E2.1.8, E2.1.9**

The overhead industrial busway catalog number has changed. For all sheets referenced above modify all key notes referencing "Overhead Industrial Busway" accordingly:

1. Remove "IP65" and replace with "IP54, 22,000AIC".
2. For 400A rated busway modify catalog number to "P-4-G-C-04-X-IP54-X".
3. For 600A rated busway modify catalog number to "P-4-G-C-06-X-IP54-X".

All overhead industrial busway additional plug-in units shall be IP54 rated and be equipped with ground fault protection.

**END OF ADDENDUM NO. 4**