



ARCHITECTURAL DESIGN ASSOCIATES, P.C.  
7501 'O' STREET, SUITE 105  
LINCOLN, NEBRASKA 68510

**August 19, 2014**

**Bradshaw Fire Department, New Fire Station  
Bradshaw, NE.**

---

**ADDENDUM #1**

The Architect issues this addendum to for distribution to all Contractors and suppliers before receipt of proposals.

**Specifications**

**Item No. 1-1**

- A. Section 00 21 13 Instruction to Bidders: Replace part 7.02 A as follows: "This project is tax exempt."
- B. Section 00 41 00 Bid Form: Delete Part 1.05, C. The project is tax exempt
- C. Section 07 21 00 Thermal Insulation, Part 2.02 A 10: add "Diversifoam Certifoam 15 is an approved manufacturer subject to compliance with requirements."
- D. Section 08 11 13 Hollow Metal Doors, Part 2.02 A: add "Mesker Door and Hardware as an approved manufacturer subject to compliance with requirements."
- E. Section 08 43 13 Aluminum Framed Entrances and Windows, Part 2.01 B: add "Manko Window Systems is an approved manufacturer subject to compliance with requirements."
- F. Section 12 35 13 Metal Casework, Part 2.01 A: add "Labconco; Carroll Seating Co. as an approved manufacturers subject to compliance with requirements."
- G. Section 13 34 19 Metal Building Systems: Part 2.01 A: add "Ceco Building Systems; Freedom Steel are approved manufacturers subject to compliance with requirements."

**Architectural Drawings**

- A. There are discrepancies between the drawings and the specifications regarding the insulation values in the wall and the roof. The correct information is as follows:
  - a. Wall insulation: R-19 minimum with thermally broken "energy saver" system.
  - b. Roof insulation: R-30 minimum with thermally broken "energy saver" system.

**END OF ADDENDUM NO. 1**