



ARCHITECTURE • ENGINEERING • INTERIOR DESIGN

ADDENDUM

PROJECT: Waverly Lawson Park
Phase II Improvements
Waverly, Nebraska

ADDENDUM NUMBER

AD-2

ISSUED BY:

Leroy Svatora, Architect
Frank Doland, Civil Engineer
Darin Sperling, Structural Engineer
Brandon Sire, Mechanical Engineer
Jon Dalton, Electrical Engineer

PROJECT #: 14-0166

DATE ISSUED: Monday, September 15, 2014

This addendum is issued by the Architect to all known bidders before receipt of proposals, for the purpose of explaining, interpreting, or modifying the original plans and specifications. When enumerated by the bidder upon the proposal sheet, the information or instructions given hereon will be equally binding upon all parties as if included in the original plans and specifications.

BIDDER MUST ENTER THE NUMBER OF THIS ADDENDUM ON HIS PROPOSAL SHEET

THE FOLLOWING ITEMS ARE APPLICABLE TO THE SPECIFICATIONS:

AD-2, ITEM 1:

In reference to Section 000107 - Seals Page, Revise Civil Engineer: Frank J. Doland's address to read:

Alfred Benesch & Company
825 J Street
Lincoln, Nebraska 68508
Phone: (402) 479-2412

THE FOLLOWING ITEMS ARE APPLICABLE TO THE DRAWINGS:

AD-2, ITEM 2:

In reference to Sheet A-101C, Plan Detail 6, revise 12"x8" Precast Paver to 12"x6" Precast Paver, color shall match Endicott's, Medium Ironspot 46, Smooth.

AD-2, ITEM 3:

In reference to Sheet A-601, Door Type Schedule, Type SP-1, Overhead Sectional Door, Revise Face Material to 25 Gauge Galvanized Steel Minimum.

AD-2, ITEM 4:

In reference to Sheet E-101, under Underground Raceway Notes, revise note A to read: "FOUR 2 1/2" CONDUITS FOR 400 AMP SERVICENOW, WITH PROVISIONS FOR FUTURE EXPANSION."

END AD-1