ADDENDUM NO. 1

Project: NDOR-Minden Re-Roof Project

Issued: September 23, 2014

Bid Date: September 25, 2014 at 3:30 P.M.

This Addendum is issued to all known plan holders before receipt of proposals.

The following shall be included with, and considered a part of, the original contract documents to the same extent as if they were included therein, for the construction of the above mentioned project. The Project Manual and Drawings shall be modified or revised as herein described. Where at variance with the original work, this Addendum shall have precedence.

This Addendum modifies the original Bidding Documents. The Bidder must acknowledge receipt of this Addendum in the space provided on the Proposal Form. Failure to do so may subject bidder to disqualification.

ADDENDA ITEMS:

AD1.1. The roof ballast can be piled next to the building in one area and the Owner will move it to another area on the Yard.

AD1.2. Clarification: Some notes refer to the existing roof having a 1/6" slope. The existing roof has a 1/16" per foot slope.

AD1.3. Further information regarding the sensitive antenna; Should the antenna get bumped or damaged, the Owner estimates the repair costs might be as much as $15,000 to $20,000

END OF ADDENDUM NO. 1

209 South 9th Street **402.475.1787 Tel.**
Lincoln, Nebraska 68508 **402.475.1800 Fax**