



ARCHITECTURE • ENGINEERING • INTERIOR DESIGN

## ADDENDUM

**PROJECT:** Nebraska Department of Correctional Services  
Cornhusker State Industries - Program 921  
TSCI - N2 Addition  
Tecumseh, Nebraska

### ADDENDUM NUMBER

AD-2

### ISSUED BY:

Mike Wachal, Coordinating Professional  
Greg Smith, Architect  
Darin Sperling, Structural Engineer  
Brandon Sire, Mechanical Engineer  
Brian Meyers, Electrical Engineer

**PROJECT #:** 14-0043

**DATE ISSUED:** Friday, February 13, 2015

*This addendum is issued by the Architect to all known bidders before receipt of proposals, for the purpose of explaining, interpreting, or modifying the original plans and specifications. When enumerated by the bidder upon the proposal sheet, the information or instructions given hereon will be equally binding upon all parties as if included in the original plans and specifications.*

**BIDDER MUST ENTER THE NUMBER OF THIS ADDENDUM ON HIS PROPOSAL SHEET**

### THE FOLLOWING ITEMS ARE APPLICABLE TO THE SPECIFICATIONS:

#### AD-2, ITEM 1:

In reference to **012300 - Alternates**, under Article 3.1, Paragraph A, revise Sub-paragraph 1 to read as follows:

1. Add Alternate: Alternate A-1 Base bid provides or the painting of the ceiling with HBPAE and painting of interior precast wall enclosure 16'-0" above finish floor. All exterior painting to be performed in the base bid by contractor. Provide add alternate to complete painting systems for interior partitions, ceilings and metal surfaces up to the elevation of 16'-0" above finish floor.

#### AD-2, ITEM 2:

In reference to **Section 224000 – Plumbing Fixtures**, add the following as Article 2.8, Paragraph A, subparagraph 1 and 2 :

#### 2.8 WALL HYDRANTS

- A. Basis of Design Product: Subject to compliance with requirements, provide the product indicated on Drawings or a comparable product by one of the following:
  1. Woodford
  2. Watts Drainage
  3. Zurn

**AD-2, ITEM 3:**

In reference to Section 224000 – Plumbing Fixtures, add the following as Article 2.7, Paragraph A, subparagraph 3 and 4 :

3. Guardian
4. Powers (Mixing Valve)

**THE FOLLOWING ITEMS ARE APPLICABLE TO THE DRAWINGS:**

**AD-2, ITEM 4:**

In reference to Sheet S-100, see attached file P1.1\_S-100 for revisions to the foundation plan.

**AD-2, ITEM 5:**

In reference to Sheet A-601, on Detail 16 revise note to steel rod to read " 1" DIA. HARDENED TOOL RESISTING STEEL ROUND BARS SPACES 6" O.C. IN HORIZONTAL DIRECTION WELDED TO FRAME, TYP."

**AD-2, ITEM 6:**

In reference to Sheet A-101, the bollards at Door N159F are existing and to remain. The bollards at Door N159g are existing and to remain. Disregard reference to Detail 3/S-503 at these locations.

**AD-2, ITEM 7:**

In reference to sheet A-102, revise ceiling note #3 to read "See Alternate #A-1 in specification Section 012300."


**AD-2, ITEM 8:**

In reference to Sheet A-601, for the Room Finish Schedule, revise Break Room N151 ceiling to read "GWB-Paint." Ceiling pads for Office N152 and Staff Toilet N157 are 24" x 48".

**AD-2, ITEM 9:**

In reference to Sheet AD-101, see sheet for temporary wall construction notes for dust and security mitigation.

**END AD-2**



**Lincoln**  
 1221 N Street, Suite 600  
 Lincoln NE 68508  
 Phone 402-476-9700  
 Fax 402-476-9722

**Vermillion**  
 15 East Main, Suite 201  
 Vermillion SD 57069  
 Phone 605-624-1081

**DAVIS DESIGN**  
 ARCHITECTURE ENGINEERING INTERIOR DESIGN

Client Information  
**Nebraska Dept. of Corr. Svcs.**  
 Tecumseh, NE

Project Information  
**Area "N2" Addition**

|  |             |
|--|-------------|
| Issue Date                                   | 02-12-15    |
| Job #  | 14-0043     |
| Drawn by:                                    | ...         |
| CADD file:                                   | S-100.dwg   |
| COPYRIGHT © DAVIS DESIGN ALL RIGHTS RESERVED |             |
| Drawing Title<br>Drawing Title and Subtitle  |             |
| From Sheet:                                  | for CA use: |
| S-100  |             |
| Drawing #                                    | P1.1        |