



ADDENDUM NO. 1

Project: Wayne State College South Student Center Roof Replacement Project

Issued: 02/17/2015

Bid Date: Tuesday, February 24, 2015 at 2:00 P.M.

This Addendum is issued to all known plan holders before receipt of proposals.

The following shall be included with, and considered a part of, the original contract documents to the same extent as if they were included therein, for the construction of the above mentioned project. The Project Manual and Drawings shall be modified or revised as herein described. Where at variance with the original work, this Addendum shall have precedence.

This Addendum modifies the original Bidding Documents. The Bidder must acknowledge receipt of this Addendum in the space provided on the Proposal Form. Failure to do so may subject bidder to disqualification.

ADDENDA ITEMS:

AD1.1. Revision to Detail 2A2.1, The lower portion of the existing 2-piece flashing shall be removed and replaced rather than be re-used. Pre-Finished color shall match the color selected for all edge metal.

AD1.2. The sloped portion of roof (Approx. 3:12 slope) shall receive a base layer of 5/8" fire rated Dans-Deck to meet fire rating requirements for a sloped roof, prior to installation of specified insulation.

END OF ADDENDUM NO. 1

