

February 27, 2015

ADDENDUM C

TO DRAWINGS AND SPECIFICATIONS FOR:

Saint James Catholic Church  
Phase 1 Renovations and Additions  
Kearney, Nebraska  
RDG Project No. 2013.203.01, File 35.1

RDG Planning & Design  
900 Farnam on the Mall, Suite 100  
Omaha, NE 68102-5089  
(402) 392-0133

NOTICE TO BIDDERS

This Addendum modifies the original Contract Documents and Project Manual dated January 28, 2015. Bidders must acknowledge receipt of the Addendum on the Bid Form.

Unless otherwise indicated, the work described herein shall comply with, and be equal in all respect to, the original Contract Specifications and Drawings. Include all incidental work required to properly complete the work whether stated herein or not.

ADDENDA TO THE PROJECT MANUAL

Architectural Specification Items

CGS-1 Section 00 41 13 – Alternates, **Addendum A**, Item AGS-3, Items G and J, and **Addendum B**, Item BGS-1 (Bid Form):

- A. Alternate No. 7 Clarification: Roofing insulation base layer of two-inch rigid insulation board is for all re-roof locations identified under the Base Bid (not including additional shaded areas shown on Sheet A4.01).
- B. Alternate No. 10 Clarification: Re-roofing of additional areas is identified as the shaded portion of the Roof Plan, Sheet A04.01.

Structural, Mechanical, and Electrical Specification Items

No items this addendum.

ADDENDA TO THE DRAWINGS

Architectural Drawing Items

CGD-1 Sheet ADO.01, Detail A1/ADO.01, Keynote 10: Revise to read:

- 10. CMU wall to remain. Provide Door Lintel 12/S7.02 at new door location.**


Structural, Mechanical, Electrical, and Audiovisual Drawing Items

No items this addendum.

ALL OTHER REQUIREMENTS OF THE PLANS AND SPECIFICATIONS REMAIN IN EFFECT. THIS ADDENDUM SHALL BE ATTACHED AND MADE A PART OF THE PLANS AND SPECIFICATIONS.

RDG PLANNING & DESIGN

By \_\_\_\_\_



Randall L. Milbrath, AIA  
for RDG Schutte Wilscam Birge, Inc.

END OF ADDENDUM C

RLM/jm

ST. JAMES CATHOLIC CHURCH  
PHASE 1 RENOVATIONS  
AND ADDITIONS  
KEARNEY, NEBRASKA  
2013.203.01