

**TO: PLANHOLDERS**  
**ADDENDUM NUMBER TWO**

**DATE ISSUED: December 1, 2015**

**RE: Jefferson County Courthouse**  
**Fire Code Improvements and Lighting Project**  
**411 4<sup>th</sup> Street**  
**Fairbury, Nebraska**

**BERGGREN ARCHITECTS**  
**PROJECT NO: 201302-302**  
**NUMBER OF PAGES (Including Attachments): TWO (2)**

*The Architect issues this addendum to all plan holders of record. This addendum amends only those portions of the plans and specifications described below and all other portions remain unchanged and in full effect.*

**PRIOR APPROVAL - ELECTRICAL**

**See ETI Addendum (attached) for a list of light fixtures given “Prior Approval”**

**CHANGES TO THE SPECIFICATIONS**

**ITEM NO. 1: SECTION 09 5100 Acoustical Ceilings**

**PART 2 – Products, Metal Suspension System**

**b. Color: was called out as Blizzard White, Change to White.**

**c. Acceptable Product: was called out as Suprafine ML 9/16  
Change to Suprafine XL 9/16 Intermediate.**

**B. Edge Moldings and Trim: was called out as 7809, Change to 7804**

**CHANGES TO THE DRAWINGS**

**ITEM NO. 1: SHEET E-302**

**See ETI Addendum (attached) for note change to this sheet.**

.

**END OF ADDENDUM TWO**



**BERGGREN ARCHITECTS**  
1201 'O' Street, Suite 302  
Lincoln, NE 68508  
402-475-0597



DATE ISSUED December 1, 2015

ADDENDUM # 2

ENGINEER Engineering Technologies, Inc.
825 M Street, Suite 200
Lincoln, NE 68508

PROJECT Jefferson County Courthouse

ETI PROJECT # 2014-161

The Architect issues this Addendum to all known bidders before receipt of proposals. Bidder shall acknowledge the receipt of this addendum on their proposal sheet and all information contained herein shall become a part of the contract documents.

ADDENDUM:

PRIOR APPROVAL – ELECTRICAL

1. The following manufacturers have received prior approval for bidding purposes subject to shop drawing review:

- A. List Equipment Here
Light Fixture #1 & 1E
Light Fixture #2
Light Fixture #3 & 3E
Light Fixture #4
Light Fixture #5 & 5E
Light Fixture #7
Light Fixture #8 & 8E
Light Fixture #9
Light Fixture #10 & 10E
Light Fixture #11
Light Fixture #12
Light Fixture #13
Light Fixture #17
Light Fixture #19
Light Fixture #22

- List Manufacturer Here
Lithonia
Peerless
Prescolite
Eclipse, Prudential
Lithonia
Eclipse, Prudential
Axis
Mark, Finelite
Prescolite
Mark, Finelite
Compass
Compass
Compass
Lithonia
Dual Lite

DRAWINGS – ELECTRICAL

- 1. Sheet E302 Second Floor Electrical Plan
A. Sheet Note #15 indicates to provide 3 intercom stations at each window. Only one station per window is required.
B. In County Court Clerk 217 the sheet note #5 located at the service window should be changed to note #15.

END OF ADDENDUM