

addendum

addendum no. 2

date: December 21, 2015

bid date: December 22, 2015

project name: Southeast Community College Data Center

project no: 15080

This addendum is hereby made a part of the contract documents to the same extent as if it were originally included therein. Contract documents shall be considered modified or revised as hereinafter described.

mechanical items

clarification:

1. The data center room shall be protected by an Ansul Sapphire fire protection system. There is no UPS room. The agent/system shall protect the entire main data room space/floor, ceiling cavity, and floor cavity of the room. A graphic annunciator is not required.

end of addendum