



DATE ISSUED January 4, 2016

ADDENDUM # 1

ENGINEER Engineering Technologies, Inc.
825 M Street, Suite 200
Lincoln, NE 68508

PROJECT Southeast High School Chiller/AHU Replacement

ETI PROJECT # 2015-155

The Architect issues this Addendum to all known bidders before receipt of proposals. Bidder shall acknowledge the receipt of this addendum on their proposal sheet and all information contained herein shall become a part of the contract documents.

ADDENDUM:

GENERAL ITEMS – SPECIFICATIONS

- 1. Prebid attendance sheet is attached.
2. As a clarification, all owner furnishings will be moved by the owner in areas where work will be done. If there is something that is in the way of the contract work, the Contractor shall coordinate with the school to have it moved.

PRIOR APPROVAL – MECHANICAL

- 1. The following manufacturers have received prior approval for bidding purposes subject to shop drawing review:
A. List Equipment Here List Manufacturer Here
Heat Pump Balancing Valves PRO Hydronic Specialties
Heat Pump Branch Line Balancing Valves PRO Hydronic Specialties
B. Modular Chiller
i. Bidders may at their discretion provide a voluntary bid alternate with pricing for "Tandum" modular chillers. Bidders should only price this chiller as an alternate and should price the originally specified Multistack for the base bid.

END OF ADDENDUM



Pre-Bid Conference - Attendance

December 22, 2015 @ 3:30pm
LPS - Southeast High School
*Chiller/AHU Replacement Project
LPS Sealed Bid No.: 8391
ETI Project No.: 2015-155

NAME	COMPANY	PHONE	EMAIL
Chuck Carmali	Carmali Const	402-681-6276	Chuck@CarmaliConstructionW.com
Aaron Schulze	Dickey - Hinds - Blair Inc.	402-610-1105	aaron.schulze@ dickey hinds.com
Troy Foster	Cornhusker Htg.	402-464-3159	tfrey@cornhuskerhtg.com
Mark Hubbard	Tyc	402-532-4754	mark.hubbart@weldingai.com
Ron Runyan	Vision Mechanical	402-466-0087	ron@vmech.net
Phil Cook	Capitol City Electric Inc.	402-426-7435	pcook@capitolcityelectricinc.com
Kurt Sander	Walwinger	402-616-4221	KURT.SANDER@WALWINGER.COM
Dave Harrell	Control Services	402-339-4344	dharrell@controlservices.com
Ted Muckey	GIRLHOWARD MECH	402-342-1911	TIMUCKEY@GIRLHOWARD.COM
John Schuber	Nifco Mechanical	402-477-0666	J.Schuber@NifcoMechanical.com
Carl Ewing	Hayes Mechanical	402-810-1402	cewing@hayesmechanical.com