

645-022-15

ADDENDUM NO. 1

The Architect/ Engineer issues this addendum, applicable to the above named project, to all known Contractors before receipt of proposal.

This addendum includes Item Number 1-1 thru 1-5. This addendum item shall be fully incorporated into the Bidding/Contract Documents and have the same force and effect as though originally included.

The Bidder shall acknowledge receipt of this Addendum No. 1 on the Bid Proposal Form in the place provided.

GENERAL

Item 1-1: Pre-Bid Meeting Attendance Sheet

Attached is the sign-in sheet from the Pre-Bid meeting.

ARCHITECTURAL

Specification

Item 1-2: Section 09 67 23 – Ceramic Carpet System

- Add the following subparagraph to 1.2 SUMMARY:
 - B. Contact Surface Sealers Inc. for information about the existing Ceramic Carpet system.
- Delete paragraph 3.2.H and replace with the following:
 - H. Grout Coat: 3745 Self-Leveling Epoxy.

MECHANICAL

Specification

Item 1-3: Section 21 13 13 – Fire Suppression System

Delete paragraph 1.6.A and replace with the following:

- A. Hydraulic Calculations, Product Data, Shop Drawings: If required by authority having jurisdiction (AHJ) including Fire Marshall; Hydraulic calculations, product data, and shop drawings shall bear stamp of approval of AHJ and shall be sealed by a licensed Professional Engineer registered in Nebraska (if required by AHJ). It is the responsibility of the contractor to review scope of work shown on drawings and in specifications and determine if stamp and seal requirements listed in this paragraph are required by AHJ.

645-022-15

Item 1-4: Section 23 09 00 – Digital Control Equipment

Add the following subparagraph to 1.2 SUMMARY:


- B. Contact James (Jeff) Plumbtree with Johnson Controls Inc. at (605)-212-2747 for information about the existing Johnson Controls building management system.

Item 1-5: Section 23 31 16 – Ductwork Accessories

Note that subject to all drawing and specification requirements, the following are approved manufacturers for fire dampers:

- a. Greenheck

END OF ADDENDUM NO. 1



Job: _____

Job No.: _____ By: _____

Date: _____ Page _____ of _____

Sign-IN:

Name	Company	Phone	E-mail
Rayne Faus	Faus Construction	402-684-3892	rauf@fausconstruction.com
Les Swanson	BULLSEYE FIRE SPRINKLER	402-371-8754	BULLSEYE@COMPINT.COM
Brad Schultz	Stan Ortmeier & CO.	402-528-3921	SOC@GPCOM.NET
John Maguire	Tessiers Inc.	609 360 1484	
Kevin Crippen	Tessiers inc.		John.Maguire@tessiersinc.com
Faith Smith	WSC	4023757244	RUSMITH1@WSC.EDU
John Kiehl	WSC		JKIEHL@WSC.EDU
TATE NELSON	OCC BUILDERS	402-375-2180	tnelson@otteconstruction.com
Ron Loggins	WSC	4023757045	rologgi1@wsc.edu
Vaughn Kelso	TLEP	402-477-9291	
James Beecher	TLEP	816-474-8237	