



ADDENDUM #1

23 May 2016

Page 1 of 1

PROJECT: Youth Emergency Services Outreach
Center Renovation

PROJECT #: M15050

DATE: 23 May 2016

This Addendum is issued by the Architect to all bidders of record prior to receipt of proposals. Bidders shall acknowledge receipt of this addendum by so indicating on the Proposal Form. Failure to do so may subject Bidder to disqualification.

All information and instructions given herein shall become a part of the Contract Documents.

ARCHITECTURAL

1. Sheet A1.1 – H16/A1.1
 - i. Omit door 132A from project
 - ii. Provide closer at door 130A

MECHANICAL / ELECTRICAL

2. Sheet E1.1 – A4/E1.1
 - i. Provide Lithonia #AFN EXT emergency battery light mounted on exterior of building above each of three (3) exit doors (existing from Entry 121, existing from back corridor, 130B). Confirm fixture finish with Architect prior to ordering. Available finishes are white, black, brushed nickel, or dark bronze. Connect emergency lights to nearest exit lighting circuit in the building.

END OF ADDENDUM